

All Bidders**Amendment -I**

Subject: Supply, Installation, Testing and Commissioning of Kitchen Equipments at AIIA, Sarita Vihar, New Delhi.

IFB No. : HSCC/SES/AIIA/Kitchen/2013

Dear Sir,

This has reference to above IFB No. for the Subject works.

The following Amendment may be noted which shall be treated as part of the contract to be submitted duly signed & stamp along with tender.

	Bidder's Query	Amendment/Clarification
1.	M/s Klas Products Pvt. Ltd. Item No. 14 Please give size of SS Angle for SS Frame work.	1 ¼" side for sq. leg / 1 ¼" dia for tubular leg
2.	Item No. 29 The size of Refrigerator given in tender 1200 x 650x2100 & capacity 1000 Lt. The above size does not accommodate above capacity. Please fix one specification between size and capacity.	Size of refrigerator should be to accommodate 1000 Lt. capacity.
3	Item No. 37 The Thickness of top plate mentioned in tender 1 mm thick but technically it should be 16 mm thick. Please clarify.	Item No. 37 The Thickness of top plate may be read as 16 mm thick.
4	Item No. 41 The Exhaust hood mentioned in tender (Island type) and width of exhaust hood is given as 750 mm. Please clarify above exhaust hood should be Island type or wall type.	Exhaust hood would be Wall Type.
5	Item No. 43 & 69 Item mentioned in BOQ SS Chapatti Rolling table with granite top and u/s on castor but in technical specification given adjustable bullet feet please clarify.	Adjustable Bullet feet required.
6	Item No. 51,66 & 77 SS Exhaust hood with SS filter (Island type) specification not given. Please mention.	Exhaust hood only hung from ceiling.
7	Item No. 54 & 80	100 Liters

	Please specify capacity or size of Garbage Bin.	
8	Item No. 65 The Thickness of top of chapatti plate given in tender 12mm thick, it should be 16 mm thick.	The Thickness of the top of chapatti plate should be 16mm. thick.
9	Item No. 72 SS work table with drain board does not match with item No. 17. Please give specification.	Item No. 72 SS Work Table with Drain Board Marine edged top of 16 SWG SS sheet on MS Angle Frame work duly rust proof painted on SS Sq/tubular leg with adjustable bullet feet. Also fitted with u/s and a back plate.
10.	Item No. 81 SS Tray cutlery trolley size not given in tender. Please specify.	Size : 600 mm x 600mm x 750mm
11	Item No. 92 Item does not match with Item No. 94, please give specification properly.	Item No. 92 Top of 16 gauge SS sheet from MS Angle frame work duly rust proof painted, on SS Sq. leg with adjustable bullet feet. Also fitted with SS hinges to hold the 10 Nos. Dish Washing rack of size 500mmx500mm.
12	Item No. 101 Item does not match with Item No. 17, Please give specification properly.	Item does not match with Item No. 17 may be read as Item No. 101 Plate Dispenser Top of 16 SWG SS sheet on SS Angle frame work on SS square legs (1 ¼” side) with adjustable bullet feet for uneven floors. Also fitted with a back splash and under shelf. The top is fitted with stud welded both with the frame for sturdy and stronger grip size 800mm x 400mm x 850mm.
13	Item No. 102 Given specification of top in 19SWG but availability of SS sheet in 18 or 20 SWG please clarify gauge of top.	SS sheet top may be taken as 18 SWG.
14	Item No. 104 Item does not match with item No. 17 please give clear specification.	Item No. 104 Plate Cover Dispenser -

		Deleted
15	Item No. 106 Please clarify size and number of shelves of SS Rack.	900 mm x 450 mm x1800 mm.

Bidder should follow the tender terms & condition for the unanswered queries.

All other terms & conditions remain unchanged.

CGM (D&E & Projects)