

**All Bidders****Amendment -II**

**Subject: Construction, Testing, Commissioning, Validation and other associated works of Bio Safety Level-2 & 3 (BSL-2 & BSL-3) Laboratory on 'Turnkey Basis at Convergence Block, AIIMS, New Delhi.**

**IFB No. : HSCC/SES/BSL/AIIMS/2017 dated 23.06.2017**

Dear Sir,

This has reference to above IFB No. for the Subject works.

The following Amendment may be noted which shall be treated as part of the contract to be submitted duly signed & stamp along with tender.

Sr. No.	Bidder's Query	Clarification/Amendment
1.	We ourselves have an in-house expert HVAC team which has successfully executed multiple projects. Looking at the criticality of the proposed work in tender document, outsourcing the work to some other vendor will create a dependency for us as HVAC is a critical & important part in this tender	Approved names of HVAC subcontractors are deleted.
2.	Approved Makes of Chiller :  The name of Bluestar is not there in the approved make list. Having worked with Bluestar in the past, we propose that their name be included in the approved vendor list for Chillers. They are a professional organization who have always made sure of timely deliveries, installation & commissioning work. We are satisfied with their service. We request you to approve Bluestar as an approved make.	Approved Makes of Chiller :  Scroll Chiller –  Carrier/Trane/York/Danhum bush/Bluestar/Voltas
3.	Approved Electrical Panel Makes:  For body construction of control panels we propose that CPRI approved vendors be included in approved make list. The components used inside will be as per approved make list given in tender.	Tender terms prevail
4.	Approved Biosafety cabinets:  The tender document mentions that the equipment must be	- Biosafety cabinet should be NSF-49 compliant. - Approved makes of BSC

	<p>NSF/EN compliant. We are happy to introduce our own Dyna make Biosafety cabinet which is India's first EN12469 &amp; CE certified Biosafety Cabinet.</p> <p>Our BSC's are being used by prestigious Companies/Institutes/Organisations across the country and abroad.</p>	are deleted.
5.	<p>Others:</p> <p>We request you to consider and include the following makes in the approved makes list.</p> <ul style="list-style-type: none"> <li>a) Power Cables-Polycab</li> <li>b) 2/3 Way Valves- Honeywell</li> <li>c) VAV-Systemaire</li> </ul>	<p>Others:</p> <ul style="list-style-type: none"> <li>a) Tender terms prevail</li> <li>b) Johnson Controls/Belimo /Danfoss/Siemens /Honeywell</li> <li>c) Johnson Controls/Belimo /Trane/Trox/Caryaire /Systemaire</li> </ul>

Bidder should follow the tender terms & condition for the unanswered queries.

All other terms & conditions remain unchanged.

Chief General Manager  
For & on behalf of Director (AIIMS)