

HSCC/BU-II/NVARI/AYUSH-LKO/2012

Date: 13.06.2012

To,

All Bidders

Amendment-1

Subject: Supply Installation, testing & commissioning of Modular Type Office and Laboratory furniture's & associated works etc at NVARI&H, Lucknow.

Dear Sir,

This has reference to the pre bid meeting held on 11.06.2012 at 15:00 hrs for the subject work at HSCC corporate office, Noida,

The following AMMENDMENT-1/CLARIFICATION-1 may be noted, which shall be treated as a part of the contract to be submitted duly signed & stamp along with tender/contract **to be submitted duly signed & stamp along with tender envelope no. - 2:**

SI. NO	Queries raised by bidders	Clarifications
1	In item no. 1 - Table for Scientist room . Side unit not mentioned in specs but mentioned in BOQ. Please confirm if to be provided or not?	In item no. 1 : Please provide Side Unit as per BOQ
2	In item no. 9 - Bed . It is mentioned in first line that "Supply & fixing single bed without box of an overall size 900(L) x1800(B) x450(H)" Please Clarify if Box is to be provided or not?	In item no 9 : First line may be read as "Supply & fixing single bed with box of an overall size 900(L)x1800(B)x450(H)".
3	In Item no. 12 - Center table, sizes & quantity are mentioned as "1200x600x450- 1 No. "1200x600x450- 4 No.	In Item no. 12 : Sizes & quantity may be read as : "1. 1200x600x400 – 1 No. and 2. 900x500x400 – 4 Nos."
4	In item no. 18, closed steel rack size not mentioned	In item no. 18 : Closed Steel rack size may be taken as : "1800x900x375"
5	Chemical Storage – Size in BOQ = 1000x486x1800 In Drawing = 900x500x1975. Please	In item no 20 : Chemical Storage – Size may be taken as : "900x500x1975" as per drawings only

	Clarify.	
6	Item no. 11 & 12 – In BOQ understructure with a shelf of chrome plated legs is mentioned? In Drawing –18 PLPB Please Clarify.	In Item no. 11 & 12 : understructure with a shelf of chrome plated legs shall be “ 18mm PLPB” as per drawings only.
7	Item no. 15 Dressing table – only base cabinet mentioned please confirm if mirror is required or not.	In item no 15: Please provide mirror of size 600x1050H with frame made of 12mm thick particle board & backend 3” – 18mm thick
8	Item no. 16 – Is it a open rack? Only glass rack is mentioned. No glass required as per details.	In item no 16 : Glass Rack / Book Case Providing & Fixing Glass Rack / Book Case of an overall size 915Wx325Dx1745H made of 1mm thick CRC sheet with brass lock 6 lever with duplicate keys, duly powder coated. The Book case is provided with top sliding 4 glass shutters.

Other conditions of tender will remain unchanged.

Thanking you,

Yours faithfully,

(A.K.Sinha)
Project Coordinator