Chhattisgarh Medical Services Corporation Limited

Govt. Of Chhattisgarh

HSCC/NRHM/CG/Raipur/2014(V)/01

08.11.2014

Amendment No. -2

Name of Work: Construction of 100 bedded MCH wing including internal & external Electrical, HVAC, PHE, fire fighting & developments works etc." at **Bilaspur** under National Rural Health Mission scheme (NRHM)

Tender No.: HSCC/NRHM/CG./2014 (V)/01 : dated 10.10.2014

This has reference to the above Tender Notice, the following amendment may please also be noted:

1. The following additional item is included in electrical BOQ

a) Double Pole (DP) Structure:

SI	Description of Item	Unit	Quantity	Rate	Amount
no.				(in Rs.)	(Rs.)
	Double pole structure consisting of lightning arresters, DO fuses, TPMO/GOD, disk and pin insulators with stringing of conductor, as per state electricity board requirements, from MEDP to 400 KVA Transformer's terminals complete for receiving 11 KV triple pole line from state electricity board and its connection to transformer. The height of the pole will be as per state electricity board requirements. Erection of pole will be as per relevant norms of state electricity board including double coating red oxide & silver paint etc. Anti climbing device, operating handle of TPMO(GOD),stay set (stay rod +stay wire), danger notice board ,coil	Job work	1		(Rs.) 250000.00
	earthing of pole and other relevant items required for proper functioning of double pole in all respects.				
	<u>Note:</u> Transformer will be mounted on a masonry foundation adjacent to double pole structure as				
	per the requirement of state electricity board.				

b) List of Makes:

Following amended make list with respect to transformer and MCCB:

Transformers	Seimens/ ABB/ Crompton/ GE/ Voltamp
Moulded Case circuit breaker (MCCB)	L&T- D sine/ Seimens-VL/ ABB-TMA/ Schneider(NSX-NS)/ GE record plus

- c) Item No: 1.01 i.e HT Panel stands deleted
- d) **Fencing:** Fencing of Double Pole structure including Transformer will be done as per the requirements of state electricity board.
- e) Percentage quoted by the agency for electrical subhead will be applicable for above additional item also.
- 2. The validity of earnest money Bank Guarantee (B.G.) will be calculated from the original date of submission mentioned in NIT(i.e. 03.11.2014)
- **3.** Any additional/extra item which is not covered in BOQ (Volume-V) required to execute for completion of work and available in concern DSR, will be paid based on DSR rate with the percentage quoted by agency on DSR items or market rate analysis if not available in concern DSR.

Please note that this amendment shall form part of the tender and other terms & conditions of the tender shall remain unchanged.

On Behalf of Chhattisgarh Medical Services Corporation Limited. (Govt. of Chhattisgarh). Dy General Manager (Civil) HSCC (India) Limited.