

05-12-2012

“REPLY TO BIDDERS QUERIES AND AMENDMENT TO TENDER”:-

Sub. Establishment of 1.5 KWP Photovoltaic system (SPV) for HSCC Corporate Office.

Tender No.: HSCC/HO/SPV/2012

Date: 04-12-2012

CLARIFICATION/AMENDMENT NO.-I

S. No.	Queries Raised	Reply
1	The battery shall be of 12V-75AH@c/10 discharge rate of low maintenance lead acid tubular Acid battery (LMLA Tubular)	75AH or more 12 V, LMLA tubular battery can be accepted as per the manufacturer standard practice.
2	The system voltage can be of 24V instead 48V as per industry practice	System voltage will be 24V/48V as per manufacturer standard practice
2	The charge controller shall be of PWM type only as MPPT is not suitable for low wattage systems	Controller will be PWM type or MPPT as the case may be or as per manufacturers practice.
3	The efficiency of PCU shall be $\geq 85\%$ instead of 90%	Efficiency shall be $\geq 85\%$ as per MNRE is acceptable.

Please note that the above amendment shall form part of tender. This should be submitted duly signed and stamped by the bidder along with the bid in envelop no. 3 (Price bid). All other terms and conditions of tender remain unchanged.