

HSCC/Mauritius/Flacq/2019

Dated 01.11.2019

All Bidders

AMENDMENT-1

Subject: Tender for Construction of Teaching Hospital at Flacq, Mauritius.

Dear Sir,

This has reference to the pre bid meeting held on 22.10.2019 at 15:00 hrs at Ministry of Health & Quality of Life, Republic of Mauritius, Level 5, Emmanuel Anquetil Building, Sir Seewoosagur Ramgoolam Steet, Port Louis, Mauritius for the captioned subject works,

Please find enclosed the Annexure-I pertains to clarifications of pre bid queries as an AMENDMENT-1/ CLARIFICATION-1.

The above shall be treated as a part of tender to be submitted online duly signed & stamp along with tender.

Other all terms & conditions of tender shall remain unchanged.

Prospective bidders are advised to regularly scan through HSCC websites <http://www.tenderwizard.com/HSCC>, <http://www.hsccltd.co.in> and Republic of Mauritius websites www.health.govmu.org and publicprocurement.govmu.org as corrigendum/amendments etc., if any, will be notified on this portal only and separate advertisement will not be made for this.

Thanking you,

-sd-
HSCC India Limited.

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
1	NIT Technical Specification Clause 1.26	As BOQ is provided by the Employer, with no Liability of design & quantification on Contractor, we presume that this is an Item Rate Tender. Please confirm	As per tender condition
2	Instruction to Applicants 6.1	We understand that Registration/ Licence in India will qualify as an International Registration. Please confirm.	As per tender condition
3	Vol II GCC 5.2	Request you to Modify as below: (7) CPWD Specification. (8) International Standard Specification - please specify which Specification.	As per tender condition
4	Vol II GCC 11.1	Request you to provide Data on Hydrological, subsurface conditions and Soil Investigation Report.	Refer SCC clause 1.1 (4) and (7)
5	Vol II GCC 6.4	Request you to consider cost compensation for any delay by the Employer for issuance of Drawings along with Time extension as per mutual agreement.	As per tender condition
6	Vol II GCC 7.2	As mentioned in Clause 6.4 All drawings shall be issued by Engineer, hence clause 7.2 for Permanent Works Designed by Contractor may not be applicable for this project. Please confirm.	As per tender condition
7	Vol II GCC 28.2	We understand that no Royalties are applicable in Mauritius. Please confirm and delete this clause	As per tender condition
8	Vol II GCC 31.2	Please specify the facilities to be provided to other contractor. Please provide the List of Other contractors expected to Work on this Project. Otherwise contractor will provide Facilities for other Contractor which shall be payable at actuals by the Employer.	As per tender condition
9	Vol II GCC 42.1	Request you to provide complete encumbrance free possession of site at once for better planning and holistic approach towards project.	Encumbrance free site will be provided for construction
10	Vol II GCC 52.2	Deviation Limit beyond which new rates should be considered for revision in contract amount shall be +/- 15%. As per CPWD Schedule F, & Clause 12.2,12.3 & 12.5.	As per tender condition
11	Vol II GCC 59.1	We understand that Nominated Subcontractors are not applicable for this Tender. Please confirm.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
12	Vol II GCC 59.3	Liability of Design of Nominated Subcontractor Packages will with Nominated Contractor. Please confirm.	As per tender condition
13	Vol II GCC 57.1	Since Specifications shall be followed as per CPWD, mode of measurement shall be as per CPWD.	As per tender condition
14	Vol II GCC 67.3	Request you to confirm Governing Law applicable for Arbitration	As per tender condition
15	Vol II GCC 67.3	Request you for three member Arbitral Tribunal, one arbitrator by each party and the presiding Arbitrator shall be appointed by the Arbitrators appointed by the parties.	As per tender condition
16	Vol II GCC 70.1	Please provide Part II of these Conditions for increase or decrease of Cost	As per tender condition
17	Vol III SCC 1.1.5	Any changes in requirement of Client/HSCC should be compensated for Time and Cost.	As per tender condition
18	Vol III SCC 32	As per clause 32 of SCC all Guarantees shall be payable to Employer means MINISTRY OF HEALTH & QUALITY OF LIFE, REPUBLIC OF MAURITIUS. However, as per the Annexure B - Proforma for Performance BG, Annexure C - Proforma for Retention Money BG, Annexure D - Proforma for Bid Security, Annexure F - Proforma for Advance BG are all addressed to & Payable to HSCC (INDIA) Ltd. Request you to change the Formats as per Clause 32 of SCC.	All Guaratees shall be in favour of Employer means MINISTRY OF HEALTH & QUALITY OF LIFE, REPUBLIC OF MAURITIUS.
19	Vol III SCC 33. C	Request you to commence the recovery of Advance after 30 % of the gross value of the work is executed and paid.	As per tender condition
20	Vol III SCC 33. F	Request you to revise the clause as per CPWD GCC Clause 1A - Security Deposit. i.e. "The person/persons whose tender(s) may be accepted (hereinafter called the contractor) shall permit Government at the time of making any payment to him for work done under the contract to deduct a sum at the rate of 2.5% of the gross amount of each running and final bill till the sum deducted will amount to security deposit of 2.5% of the tendered value of the work."	As per tender condition
21	Vol III SCC 39.2 e	Request you to provide the details along with drawings of existing under ground & Over Head Services & utilities to be shifted or dismantled.	Refer clause 4.0 of SCC Vol-III
22	Vol III SCC 39.2.5	Please provide further details like no of Occupants for the office & expected Built up area. We presume one vehicle/car is to be provided. Please confirm.	Expected built up area may be around 90 Sqm. Rest as per tender condition.
23	Vol III SCC 41	Also please provide the status of approvals if already applied by the Employer.	As per tender condition
24	Vol III SCC 42	Request you to please provide Incentive for early completion as per CPWD GCC Clause 2A.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
25	Vol III SCC 48	Request you to delete this clause as this will adversely affect the Project Cash flow and progress of work.	As per tender condition
26	Vol III SCC 39.2.2	We understand that the Land for the temporary Infrastructure will be provided free of cost within the site premises or near by, for the following, 1. Batching Plant 2. Labour Colony 3. Site Office 4. Stores, Workshop, Material yard and other Amenities required for execution. Please confirm.	As per tender condition
27	Vol V BOQ	As the project is in Mauritius and most of materials are to be imported from various countries and are to be dealt in US Dollars, we request you to kindly consider award of this contract in US Dollars instead of Mauritian Rs (MUR).	As per tender condition
28	Vol III SCC Annexure C point 7	Request you to modify the clause as below: 7. This guarantee shall be a continuing guarantee during its currency and shall remain valid and irrevocable for all claims of The Employer and liabilities of the contractor arising upto and until midnight of ___--	As per tender condition
29	Vol III SCC Annexure F point 12	Request you to modify the clause as below: 12. This guarantee/undertaking shall be a continuing guarantee/undertaking during its currency and shall remain valid and irrevocable for all claims of The Employer and liabilities of the Contractor arising upto and until midnight of _____.	As per tender condition
30	Vol III SCC Annexure B point 7	Request you to modify the clause as below: 7. This guarantee shall be a continuing guarantee during its currency and shall remain valid and irrevocable for all claims of the Employer and liabilities of the Contractor arising upto and until midnight of _____.	As per tender condition
31	Vol II GCC 1.1 (a).i	We understand that Tax Invoice to be raised in favour of Employer / Principle Employer. Kindly confirm.	Yes
32	Vol II GCC 52.1	CPWD norms are applicable in Mauritius also? Pls confirm.	Yes

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
33	Vol II GCC 54.3	Clearance of Material / Equipment in Customs will be done by employer? Kindly confirm. Clearance will be done in the name of Employer?	As per tender condition
34	Vol II GCC 54.4	Letter for extension for re export of contractors equipment will be issued by employer based on the construction of equipment. Kindly confirm.	Yes
35	Vol II GCC 60.1	Kindly confirm the rate of advance Income tax rate 2% (TDS). Kindly confirm the applicability of advance works contract tax (TDS)	As applicable in Mauritius
36	Vol II GCC 70.2	Subsequent to submission of tender any change in Law or change in rate of existing duties, Levies and Taxes both at Input stage as well as output stage will be adjusted (plus or minus) in the contract price. Kindly confirm?	As per tender condition
37	Vol II SCC 37	As this is a government project we understand that the following exemptions are available to the Contractor. Please confirm: 1) RTA - Road Transport Authority registration and charges for vehicles 2) National Pension Fund 3) National Security Fund 4) Corporate Tax 5) Income Tax	As per tender condition
38	Vol II SCC 37	Project related procurement by contractor and by consultant will also be excepted from payment of taxes. Kindly confirm	As per tender condition
39	Vol II SCC 37	Contractor billing to customer will also be excepted to pay VAT / Local taxes based on exemptions certificate. Kindly confirm.	As per tender condition
40	Vol II SCC 37	Project related procurement by sub suppliers, sub contractors, Down line supply chain will also be excepted for paying VAT / Local taxes based on the exemptions certificate. Kindly confirm.	As per tender condition
41	Vol II SCC 37	Import of construction materials, Machinery, Equipment's to Mauritius by (a) contractor (b) Consultant © Sub contractor (d) Sub agencies - will also be excepted by paying customs duty / VAT based on exemptions letter. Kindly confirm.	As per tender condition
42	Vol II SCC 37	List of equipment, machinery, vehicles to be imported will be dynamic in nature, based on construction schedule. The nodal agency will facilitate in obtaining approval for revised list also. Kindly confirm.	As per tender condition
43	Vol II SCC 37	Any delay in obtaining exemptions certificate by Nodal agency will not be account to contractor. Kindly confirm.	As per tender condition
44	Vol II SCC 37	Import of vehicle for personal use to be reexported within 3 months. Whether this period can be extended further period based on Employer's certification. Kindly confirm.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
45	Vol II SCC 37	For uninterrupted progress of work, the contractor to pay all the duties and levis if any as per government provision, with prior approval from employer. Kindly confirm.	As per tender condition
46	Vol II SCC 37	Kindly confirm the inclusion of Taxes and duties in price.	As per tender condition
47	37	Kindly confirm the applicability of Octroi in Mauritius	As per tender condition
48	General	Request you to provide the Approved Make List for Structure & Architectural items.	As per tender condition
49	General	Request you to Provide Master Plan & Site Layout.	Not required at this stage
50	General	Request you to provide the Floor wise Built Up Area Statement	Refer Architecture drawing already provided
51	BOQ	Some BOQ items mention Prime Cost. We understand that its nothing but the basic cost of material including Taxes (if applicable) and same shall be adjusted for any increase & decrease in actual cost of material selected by the employer. Please confirm.	Prime Cost (PC) means basic cost of material in local market including taxes etc as applicable
52		Request you to provide the Auto Cad drawings for your reference.	As per tender condition
53	Technical Specification 4.13	Under Section # 4.13 Steel Reinforcement, the Tender Documents have not specified clearly the current approved / legislated / legally applicable Standard No MS 10. Standard No MS 10 is the old version of 460 Mpa and not strict on chemical composition. Standard No MS 10 should read MS 10:2015 BS 4449:2005 / A3:2016 which is for 500 Mpa material and with a strict code on the Chemical Composition under A3:2016. Under this Standard one re-test is allowed on Mechanical Properties failures and very restrictive one re-test on Chemical Properties. As you may be aware all imported steel is subjected to Mauritius Standard Bureau tests both for Mechanical and Chemical Properties before release from the Port, Hence we request you to update the Specification to MS 10:2015 BS 4449:2005 / A3:2016.	MS 10 should be read as MS10:2015 (BS 4449 :2005 + A3 :2016)
54	Vol 5 BoQ	Whereas in BOQ different thickness of glass is mentioned. Please clarify which document to be followed.	Thickness of glass as given in individual BOQ item to be considered while quoting the rates.
55	Drawing No: HSCC/FLAQ/HSCC/HB/TD/09	Marble cladding is mentioned the drawing we are unable to locate in the BOQ. Kindly provide BOQ of this item	Please refer item 8.06 (BOQ civil)

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
56	Tender Drawing - HSCC/FLAQ/HSCC/HB/TD/09	Elevation and Floor plan details not matching, in Elevation Shown G, GL, GL2, and Glaze, in floor plan its shown in W1 or W2, kindly clarify	To be followed elevation.
57	Tender Drawing	Provide detailed drawing for Glazing (part elevation and Section Details)	To be followed elevation.
58	BOQ - Item No: 4.15	BOQ door size and Drawing Joinery Schedule not matching and Location of Door not clear, please clarify	Rate to be quoted as per BOQ item only
59	BOQ - Item No: 4.01, b & c	As per the BOQ all glass are given laminated clear glass. We presume for the entire project is with non performance clear glass. Pls confirm	Rate to be quoted as per BOQ item only
60	BOQ - Item No: 4.01, b & c,	Kindly provide the Window Joinery schedule showing the fixed & openable	As per tender condition
61	Vol 05_BOQ	Please provide seggregate elemt wise quantity break up for fair finish	Query not clear
62	Vol - 5 A&B Technical Specification	we shall stick to IS 456 codal provison for deshuttering and appropriate design proof shall be submitted on deviation. Please confirm.	No change in tender condition
63	Vol - 5 A&B Technical Specification	We shall use plywood that suffice IS4990 recommendation and also gives good quality finish. Please confirm	No change in tender condition
64	Volume V -BOQ	Level controllers - Kindly provide us the details technical specification along with schematic diagram for this item	As per tender condition
65	Volume V -BOQ	Insulation - Kindly provide us the technical details	As per tender condition
66	Volume V -BOQ	Kindly provide us the additional makes for insulation	Bidder has quoted their rate.
67	Volume V -BOQ	Kindly confirm the Basic price inclusive of Washbasin ,semi pedestal , was coupling & faucet	Bidder has quoted their rate.
68	Volume V -BOQ	Kindly confirm the Basic price inclusive of Washbasin ,Bottle trap , was coupling & faucet	Bidder has quoted their rate.
69	Volume V -BOQ	Kindly confirm the Basic price inclusive of urinal ,Bottle trap , was coupling & flush valve	Bidder has quoted their rate.
70	Volume V -BOQ	Pipe laying of graving sewer - Kindly confirm the IS code & PN rating	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
71	Volume V -BOQ	Pipe laying of graving sewer - Kindly provide us the MOC of cover	As per tender condition
72	Volume V -BOQ	Kindly provide us the approved make list for concealed cistern	As per tender condition
73	Volume V -BOQ	Kindly provide us the approved make list for mirror	As per tender condition
74	Volume V -BOQ	Kindly provide us the approved make list for SS grab bar	As per tender condition
75	Volume V -BOQ	Kindly provide us the approved make list for bed pan sink	As per tender condition
76	Volume V -BOQ	Kindly provide us the approved make list for surgical sink	As per tender condition
77	Volume V -BOQ	Kindly provide us the GI pipe grade heavy or medium	As per tender condition
78	Volume V -BOQ	Kindly provide us the approved make list for insulation tubing	As per tender condition
79	Volume V -BOQ	Can we consider equivalent IS code for UPVC 4985 PN -10Kg. Kindly confirm	As per tender condition
80	Volume V -BOQ	Solar water heater Each = 5000liter /day with 38 no's of Collector with heat pump kindly confirm.	As per tender condition
81	Volume V -BOQ	Kindly confirm ETP civil works weather its lies with PHE contractor scope	As per tender condition
82	Volume V -BOQ	Kindly confirm STP civil works weather its lies with PHE contractor scope	As per tender condition
83	Vol III SCC Clause 5	As This is Competitive Tender, The contractor shall have the Liberty to choose any make from the List of approved Makes Provided ,subject to Compliance to technical Specifications. Please confirm.	As per tender condition
84	Vol-4 Technical specifications	Being an Item Rate tender, Design / Design Verification/ Design validation does not fall Under the scope of the contractor. Hence request you to delete the mentioned clause. We shall quote on Item rate basis for the BOQ Provided. Any Change to the mentioned Capacities/ Quantities/ specification shall be treated as a variation. Please confirm	Shall be as per tender Conditions
85	Vol-4 Technical specifications Clause 1.1.10 (V), VI- Water Chilling Plant	In Clause 1.1.10 (v), we infer the Term : "Fan cooled for Open Type Chiller" as " Air cooled for Open Type Chiller" as mentioned in Clause 1.1.10 Clause(vi). And as Offered by approved Vendors Listed. Please confirm	Shall be as per tender Conditions
86	Vol 5- BOQ Item No 1.1	Request You to Accept HFO- R514A ,as an additional Refrigerant along with R134A ,as one of the Listed Vendor cannot Offer Centrifugal Chillers with R 134 A. Please confirm	Shall be as per tender Conditions

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
87	Vol 5- BOQ - Item No 1.1 r	Based on The Input from approved Vendors , not all of them are able to comply to Given Criterion of "The IKW/TR should not be more than 0.6 (inclusive of all losses) at duty conditions" To ensure competitive bidding Request you to amend the same as: "The IKW/TR should not be more than 0.63 (inclusive of all losses) at duty conditions". Please confirm.	Accepted
88	Vol 5- BOQ - Item No 1.1 t	Request you to accept China as an additional Country of Origin along with Europe / USA for Chillers, as the acceptable manufactures have well established facilities in China, and as per respective manufacturers sourcing Policy followed for the Region. Please confirm.	Shall be as per tender Conditions
89	Vol-4 Technical specifications- Specs AC	Kindly Provide The List of approved Makes for the Following 1) Cooling Towers 2) Hot water generator 3) Scrubbers 4) Air washer 5) Monsoon Reheat for OT & ICUS 6) Expansion tank and Air Separators 7) Ball Valves 8) Strainers 9) Check Valves 10) Grilles/ Diffusers/ Dampers/ Fire Dampers/ Louvers	Shall be as per tender Conditions
90	Vol 3 SCC_ (C)SPECIFIC CONDITIONS OF CONTRACT RELATING TO HVAC SYSTEM Clause 3.1	Being an Item Rate competitive tender, for any discrepancy Between documents, Priority of Contract documents as specified in Clause 5.2 General Conditions of Contract(Page 16) shall be followed. Please confirm.	As per tender condition
91	Vol 3 SCC_ (C)SPECIFIC CONDITIONS OF CONTRACT RELATING TO HVAC SYSTEM Clause 4.0	As This is Competitive Tender, The contractor shall have the Liberty to choose any make from the List of approved Makes Provided ,subject to Compliance to technical Specifications. Please confirm.	As per tender condition
92	Vol 3 SCC_ (C)SPECIFIC CONDITIONS OF CONTRACT RELATING TO HVAC SYSTEM Clause 4.2	We Presume the Mentioned clause is not applicable as all items on entry into Mauritius shall be accompanied with proper documentation like Bill of Lading, Country of Origin certificates etc. Please confirm.	As per tender condition
93	FF BOQ, Item No. 1.01, Ref. No. 3b. 01 & 02	Item description indicates for both types DCP (Powder type) & CO 2, request to conform which tyoe to be considered	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
94	FF BOQ, Item No. 1.03 Ref. No. 3d. 01 to 05	As per BOQ and Specifications, we are considering MS Black Steel Pipes with screwed & socket Joints, Kindly conform	As per tender condition
95	FF BOQ, Item No. 1.11 Ref. No. NS	BOQ indicates both material the materials GM & SS, kindly conform which material to be considered	As per tender condition
96	FF BOQ, Item No. 1.12 Ref. No. NS	BOQ indicates both material the materials GM & SS, kindly conform which material to be considered	As per tender condition
97	FF BOQ, Item No. 1.04 Ref. No. 3e, & Vol 4, Technical Specifications, Page 48, 83. Sprinkler Heads	We are considering Fast response sprinklers as per BOQ, and as per specification, this is of Pendant, Ceiling flush mounted type, kindly conform	As per tender condition
98	FF BOQ, Item No. 1.29 Ref. No. NS	Request to kindly conform the exact size to be considered	As per tender condition
99	FF BOQ, Item No. 1.40,a	BOQ indicates with SS Impeller, and Vol 04, Technical Specification page no.32, Clause 43.01, indicated with Bronze impeller, kindly conform which material should be considered	As per tender condition
100	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT	Being an item rate contract, design and detailed working drawings shall not be part of contractor scope of works and we presume same shall be issued by the consultant. However relevant shop drawings shall only be prepared and submitted for approval by the contractor. Please confirm.	Yes
101	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT	We presume to consider following major Electrical equipment for the inspection of Routine test performed at Factory. 1. HT Panel 2. Transformer 3. DG set 4. UPS 5. Main LT Panel 6. Lifts Please confirm.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
102	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT VOLUME-V Bill of Quantities	We presume cost of civil works such as foundations for equipment are not part of Electrical scope of works and shall be covered elsewhere in civil BOQ line item. Please confirm.	As per tender condition
103	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT	We understand CPWD specification as referred here and elsewhere in this tender NIT is Indian CPWD specifications.	As per tender condition
104	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT	We presume to consider CPWD specification for Electrical Works (Part I - Internal) -2013 being the latest published under the authority of Director General, Delhi-India.	As per tender condition
105	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT	Being an item rate contract, drawings such as reflected ceiling plan, coordination drawings with detailed sections shall be only issued by client/consultant and not be part of contractor's scope of works. However coordination at site execution shall be part of contractor scope of works.	All shop drawings shall be prepared and submitted for approval by the contractor.
106	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT	We presume that 15 days timeline starts from vendor finalisation by the contractor for the works.	As per tender condition
107	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT	Being competitive bid, we presume contractor has the liberty to choose the choice of makes among the approved makes. Please confirm.	As per tender condition
108	VOLUME-III- SPECIFIC CONDITIONS OF CONTRACT	We presume that fuel shall be provided by client for the operation of DG Sets. Please confirm.	As per tender condition
109	VOLUME-V Bill of Quantities / PHE works	Request to kindly furnish the following to consider the control cables for motor starting. 1. Cable Size 2. Cable Length	As per tender condition
110	VOLUME-V Bill of Quantities / FIRE FIGHTING WORKS	Request to kindly furnish the following to consider the control cables for motor starting. 1. Cable Size 2. Cable Length	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
111	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Being Transformer with OFF Load Tap Changer, RTCC+AVR and Related Control cables shall not be applicable. Please confirm.	RTCC, AVR and its related control cable not in scope.
112	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the following details to quote for this line item. 1. Nos. of Bends 2. Nos. of Terminations	as per actual requirement
113	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the following to quote for the earthing Station. 1. Layout and schematic drawing. 2. Length of Single core 185 Sqmm copper cable 3. Nos. of terminations of above cable 6. Type of Earth pit 7. Nos. of Earth Pits (if any).	As per tender condition
114	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	We presume this item refers to the termination of above copper cable in MV cubicle earth bar. Also unit of measurement is "Nos". Please confirm.	As per tender condition
115	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the following to quote for the transformer earthing station. 1. Layout and schematic drawing. 2. Cable Size and no.of cores 3. Conductor material (Copper or Aluminium) 4. Length of cable 5. Nos. of terminations of above cable 6. Type of Earth pit 7. Nos. of Earth Pits if any.	As per tender condition
116	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	We presume this item refers to the termination of above copper cable in each transformer. Also unit of measurement is "Nos". Please confirm.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
117	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the following to quote for the transformer earthing station. 1. Layout and schematic drawing. 2. Cable Size and no.of cores 3. Conductor material (Copper or Aluminium) 4. Length of cable 5. Nos. of terminations of above cable 6. Type of Earth pit 7. Nos. of Earth Pits if any.	As per tender condition
118	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	We presume this item refers to the termination of above copper cable in each transformer. Also unit of measurement is "Nos". Please confirm.	As per tender condition
119	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Please furnish the quantity for HT Terminations to be considered as part of this line item.	As per tender condition
120	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	We presume unit of measurement for this line item is "Nos". Please confirm.	As per tender condition
121	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the Dimensions, wiring connection details and Layout drawings to quote for this line item.	As per tender condition
122	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Please confirm shall we consider cable trays manufactured as per Indian Standards(IS) or CPWD specifications.	As per tender condition
123	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the following details to quote for this line item. 1. Nos. of Bends 2. Nos. of Terminations	As per tender condition
124	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Shall we consider FR-PVC conduits for concealed conduiting and MS painted conduits for surface conduiting. Please confirm.	as per BOQ
125	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the average wiring length to be considered for this line item.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
126	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the average wiring length to be considered for this line item.	As per tender condition
127	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the Make and Model Nos. of Multifunction Sensor against each of the approved makes to be considered for this line item.	As per tender condition
128	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the Make and Model Nos. of PIR Sensor against each of the approved makes to be considered for this line item.	As per tender condition
129	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the Make and Model Nos. of PIR Sensor against each of the approved makes to be considered for this line item.	As per tender condition
130	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Luminaire Model Nos. is not furnished. Request to kindly furnish the Model Nos. of Luminaire against each of the approved makes to be considered for this line item.	As per tender condition
131	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	IP protection and Insulation class of ceiling fans shall be as per approved manufacturer's standard offerings. Please confirm.	as per standard manufacturer practice
132	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the Make with Model No. of ceiling fan against each of approved makes to be considered for this line item.	As per tender condition
133	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the Make with Model No. of ceiling fan against each of approved makes to be considered for this line item.	As per tender condition
134	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the Make with Model No. of ceiling fan against each of approved makes to be considered for this line item.	As per tender condition
135	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Crompton Greaves make is not specified as approved in List of approved Makes document for fans. We presume makes specified in BOQ or Elsewhere in Tender is also approved in addition to the makes specified in List of approved makes. Please confirm.	As per tender condition
136	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly furnish the Make with Model No. of ceiling fan against each of approved makes to be considered for this line item.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
137	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	We presume to consider only supply and laying of cables in these line items. Please confirm.	As per tender condition
138	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly provide separate BOQ line item for pipe sleeves, expansive foam and sikaflex compound with quantities.	As per tender condition
139	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Request to kindly provide separate BOQ line item for cable Termination with quantities for all the cable sizes (SI. No. i to xvi).	As per tender condition
140	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Please confirm the material type (MS or GI) poles to be considered for this line item.	hot dipped galvanized pole
141	VOLUME-V Bill of Quantities / ELECTRICAL WORKS	Please confirm whether pole for the post top lantern is part of this line item. If yes, request to kindly furnish the following details. 1. Material (MS or GI) of the pole 2. Height of the pole.	As per tender condition
142	VOLUME-V Bill of Quantities / HVAC WORKS	We presume the power cabling, control wiring, copper earthing, terminations, wiring for micro switch shall not be considered as part of this line item as these items are separately measured under SI. Nos. 28.1, 29 and 30. Please confirm.	As per tender condition
143	VOLUME-V Bill of Quantities / HVAC WORKS	If the power cabling, control wiring, copper earthing, termination items, wiring for micro switch are to be considered part of these line item. Request to kindly furnish the following details. 1. Power Cable Size and conductor material 2. Power cable quantity 3. Power cable Termination Quantity 4. Earthing strip size 5. Control cable size 6. Control cable Quantity 6. Wiring size for micro switch	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
144	VOLUME-V Bill of Quantities / HVAC WORKS	If the power cabling, control wiring, copper earthing, termination items, wiring for micro switch are to be considered part of these line item. Request to kindly furnish the following details. 1. Power Cable Size and conductor material 2. Power cable quantity 3. Power cable Termination Quantity 4. Earthing strip size 5. Control cable size 6. Control cable Quantity 6. Wiring size for micro switch	As per tender condition
145	VOLUME-V Bill of Quantities / HVAC WORKS	We presume to consider only supply and laying of cables in these line items. Please confirm.	As per tender condition
146	VOLUME-V Bill of Quantities / HVAC WORKS	Request to kindly provide separate BOQ line item for pipe sleeves, expansive foam and sikaflex compound with quantities.	As per tender condition
147	VOLUME-V Bill of Quantities / HVAC WORKS	Request to kindly provide separate BOQ line item for cable Termination with quantities for all the cable sizes (Sl. No. 28.1.1 to 28.1.11).	As per tender condition
148	VOLUME-V Bill of Quantities / HVAC WORKS	We presume to consider the UPS and Batteries warranty up to DLP period of 1 Year. Please confirm.	As per tender condition
149	VOLUME-V Bill of Quantities / HVAC WORKS	We presume the BOQ description as specified under UPS is not applicable or relevant to Electrical Works. Request to kindly move this description to respective section.	As per tender condition
150	VOLUME-IV Technical Specification / Electrical Works	We presume to consider losses as per IS 1180-Level-2 for Transformers. Please confirm.	As per tender condition
151	VOLUME-IV Technical Specification / Electrical Works	Please confirm shall we consider Transformer in compliance with IS2026/IEC.	As per tender condition
152	VOLUME-IV Technical Specification / Electrical Works	Being item rate contract, preparation/supply of working drawing, Equipment layout drawing shall not be part of contractor scope of works. Please confirm.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
153	VOLUME-IV Technical Specification / Electrical Works	Please confirm shall we consider either Indian Standard code or British Standard code of practice, if an item or subject within the contract has not been covered either under the MS63:1995 Regulations.	As per tender condition
154	VOLUME-IV Technical Specification / Electrical Works	Being a project in Mauritius, this clause shall not be applicable.	As per tender condition
155	VOLUME-IV Technical Specification / Electrical Works	Request to kindly furnish the list of Electrical UPS Panels with BOQ serial Nos. in which the outgoing breakers to be considered with high immunity type.	As per tender condition
156	VOLUME-IV Technical Specification / Electrical Works	Various type of Electronic trip units are specified in specification. But in BOQ we have not found any reference to the type of Electronic trip units to be considered. Request to kindly furnish the type of List of Electronic releases to be considered against each of the panel breakers.	As per tender condition
157	VOLUME-IV Technical Specification / Electrical Works	Features of Electronic trip units varies among approved switchgear manufacturers. Being competitive bid, we presume to consider the approved manufacturers product as per their design standards and offerings. Please confirm.	as per standard manufacturer practice
158	VOLUME-IV Technical Specification / Electrical Works	Testing kits shall be used for the purpose of testing of switchgears and shall not be supplied along with panel boards.	As per tender condition
159	VOLUME-IV Technical Specification / Electrical Works	Approved Panel manufacturers offers IP-42 as minimum protection for Electrical Panel Boards placed within the building. Please confirm shall we consider IP-42 protection for indoor Panel Boards.	As per tender condition
160	VOLUME-IV Technical Specification / Electrical Works	Construction material and Housing design of Busduct/Rising mains shall be as per approved OEMs type tested design standard only.	As per tender condition
161	VOLUME-IV Technical Specification / Electrical Works	As an Industrial practice, MCB DBs installed within the building shall be with IP-43 protection only. We presume the MCB DBs provided in the BOQ is for Indoor application within the building and hence we presume to consider all the MCB DBs with IP-43 protection. Please confirm.	As per tender condition
162	VOLUME-IV Technical Specification / Electrical Works	We presume to consider Site assembled MCB DBs with the components such as MCBs, ELCBs. Please confirm.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
163	VOLUME-IV Technical Specification / Electrical Works	Nos of Cylinder offered for the required capacity of DG Set shall be as per the approved DG OEMs Manufacturing design standard.	as per standard manufacturer practice
164	VOLUME-IV Technical Specification / Electrical Works	DG set offered by all the Manufacturers shall be able to take the load within 10-20 Seconds from the time DG turns ON.	as per standard manufacturer practice
165	VOLUME-IV Technical Specification / Electrical Works	Please confirm shall we consider VRLA batteries.	As per tender condition
166	VOLUME-IV Technical Specification / Electrical Works	Alternator bearing type/design, cooling system offered shall be as per approved DG OEMs tested design/Manufacturing standards	as per standard manufacturer practice
167	VOLUME-IV Technical Specification / Electrical Works	Mounting arrangements and safety requirements offered shall be as per approved DG OEMs tested design/Manufacturing standards	as per standard manufacturer practice
168	VOLUME-IV Technical Specification / Electrical Works	Diesel tank shall be provided separately and shall not be part of DG Set frame as per industrial standards for 1250kVA DG set.	As per tender condition
169	VOLUME-IV Technical Specification / Electrical Works	Please clarify the scope of present contract.	As per tender condition
170	VOLUME-IV Technical Specification / Electrical Works	Equipment finish shall be as per approved DG OEMs standard offerings as per their manufacturing standard.	as per standard manufacturer practice
171	VOLUME-IV Technical Specification / Electrical Works	Please confirm whether battery monitoring system is required for automatic rescue device batteries.	As per tender condition
172	VOLUME-IV Technical Specification / Electrical Works	BOQ line item is not available. Please provide the same.	As per tender condition
173	VOLUME-IV Technical Specification / Electrical Works	Please confirm whether battery monitoring system is required for automatic rescue device batteries.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
174	VOLUME-IV Technical Specification / Electrical Works	BOQ line item is not available. Please provide the same.	As per tender condition
175	VOLUME-IV Technical Specification / Electrical Works	BOQ calls for MS finish whereas as per specification calls for SS 316 material and Vandal proof finish. Being BOQ has higher precedence, we presume to consider MS fabricated dumbwaiter. Please confirm.	As per tender condition
176	VOLUME-IV Technical Specification	Being competitive bid, we presume contractor has the liberty to choose the choice of makes among the approved makes. Please confirm.	yes, as per approved make list
177	VOLUME-IV Technical Specification	Request to kindly approve the following the makes. 1. Authorised System Integrator of approved OEMs (Siemens/L&T/ABB/Schneider)	As per tender condition
178	VOLUME-IV Technical Specification	Request to kindly approve the following the makes for HT/LT-XLPE Cables 1. RPG-India	As per tender condition
179	VOLUME-IV Technical Specification	Request to kindly approve the following the makes for Copper control Cables 1. RPG-India	As per tender condition
180	VOLUME-IV Technical Specification	Request to kindly approve the following the makes for Cable Trays/ Raceways 1. Profab-India 2. Indiana-India	As per tender condition
181	VOLUME-IV Technical Specification	Arnould is the range of the product offered by Legrand. Request to kindly provide us additional makes to be considered for this item.	As per tender condition
182	VOLUME-IV Technical Specification	Request to kindly approve the following the makes for Conduit 1. Precision-India	As per tender condition
183	VOLUME-IV Technical Specification	Request to kindly approve the following the makes for Copper conductor PVC insulated wires, Co-axial , Telephone wires & cables 1. RPG-India	As per tender condition
184	VOLUME-IV Technical Specification	Request to kindly provide additional approved makes for Ceiling fans.	As per tender condition
185	Page No. 02, Vol I	Are Joint-Ventures / partnerships between 2 or more contractors / companies allowed for the bid	As per tender condition
186	Page No. 3, Vol I and page No. 12, Vol III	Does the completion period of 22 calendar months include the time for designing, approvals by the relevant Authorities – the design part by the contractor is defined at page 12 and 13 of Vol III.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
187	Page No. 13, Vol III	Clause 6 require structural drawing, to be vetted by reputed / Government institutes in India / abroad. Can you, please, specify the relevant body in Mauritius, to which we shall refer for vetting the Structural design	As per tender condition
188	Page 28, Vol III	Clause 31.0 refers. Can the insurance be effected with reputed Mauritian insurance companies?	Bidder has to find out
189	Page 7, Vol I	Clause 10.0 refers – power to relax criteria for pre-qualification. Could you, please, explain under what circumstances will the “relaxation “takes place	As per tender condition
190	Page 7, Vol I	Clause 11.0 refers. What are the factors that may lead to disqualification of a potential bidder, even if it meets all criteria?	As per tender condition
191	Page 7, Vol I	Clause 12.1 refers. Could you clarify the meaning of “Free issued cement & steel shall be considered to arrive at final completed project cost.”	If Client issue “Free cement & steel shall be considered to arrive final completed project cost.”
192		Concerning the drawings for the different disciplines, kindly provide us with the plans “Architectural, MEP, HVAC, Furnishing and interior design in DWG format.”	As per tender condition
193		Please Provide us with all the bill of quantities (B.O.Q) in Excel form.	As per tender condition
194		Please Confirm that the technical offer and the Financial offer will be submitted online and acceptable, and only the demand draft with the bid bond will be submitted in Mauritius.	Yes , only Tender fee and Bid security shall be submitted in hard copy rest shall be online only
195		Please Confirm that the prequalification documents will be submitted one the same day of the bid submission date.	As per tender condition
196		Please clarify the Building project type is a green Building (3 stars), if yes please clarify the certificate type as example “lead – Green Star” with the score card.	As per tender condition
197	Joint venture VOL-I, P-8, 13.3	We request Joint Venture to consider this Project.	As per tender condition
198	Site Location Voll-III P-39	Kindly give Exact Site	Kindly refer drawings and rest as per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
199	Labour Camp Vol-III, P-40, 39.2.2	Request HSCC to arrange land for Labour camp, Storage and accomodation from the client.	As per tender condition
200	Water Supply & Power Supply 39.2.4 of Vol-III, P-42	What support will be rendered by HSCC to get these connections.	As per tender condition
201	General	The Estimate rate of the Item of Works to be Provided.	As per tender condition
202	Approved Makes	Makes given in the Schedule are mostly from India. Provide alternative makes that are locally available in Mauritius.	As per tender condition
203	Drawingsv General	Request to provide all the MEP drawings	All MEP drawings already given online for tendering purposes
204		Can you please clarify how to obtain the Digital Signature Certificate (DSC)? Please provide details of the Authorized Certifying Authorities.	Please Contact our IT cell
205		Please confirm if the Prequalification documents must be submitted, because they are not part of the the Clause D. 15 Submission of Bid (SCC Page No.20). If yes until what date and time.	It is mentioned that Bid documents (all pages) & drawing (Volume I, II, III, IV & VI) duly signed and stamped to be submitted online
206		In the Tender Documents there is no reference to Joint Ventures. Please clarify if Joint Ventures are acceptable.	As per tender condition
207		The project is a Lump Sum or is Re-measurable?	Item rate tender. Shall be measured
208		The peiod for the Construction of the Hospital is 22months, including Design, Approvals, Permissions and Construction?	As per tender condition
209		Clause 15.2 (SCC Page No.22), <i>No rates to be quoted for the items where nil quantity is mentioned against that item. Indicating NIL quantity does not mean that this item will not be operated in the work. Rate of item quoted under any section of Bill of Quantity is interchangeable and minimum rate quoted for the same item under any section will be taken for payment.</i> Please clarify.	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
210		Clause 37.0 Taxation (SCC Page No.38), means that we will submit our price excluding Duties and Taxes, correct?	Quoted price shall include all taxes.
211		Please provide the Bill of Quantities in excel.	As per tender condition
212		As per (SCC Page No.13) <i>The soil investigation report will be provided by HSCC to Contractor for reference purpose. However, they are required to get it done independently to satisfy themselves as per design requirements.</i> Please provide.	As per tender condition
213		Clause 10 Bid Price (SCC Page No.18), <i>Contractor under the Contract including Forest Royalty, Contractors profit and over heads etc. or for any other cost shall be included in the rates and prices and the total amount of Bid submitted by the Bidder. The evaluation and comparison of Bids by the Engineer shall be made accordingly.</i> Please clarify what is a Forest Royalty?	As per tender condition
214		Page 3 - Bidders are advised to regularly scan through HSCC websites http://www.tenderwizard.com/HSCC , http://www.hsccld.co.in and Republic of Mauritius websites www.health.govmu.org and publicprocurement.govmu.org as corrigendum/amendments etc., if any, will be notified on this portal only and separate advertisement will not be made for this. Please provide contact to assist, because we can't finalize the registration.	As per tender condition
215		The Contract is eligible to be undertaken as Joint Venture - please clarify	As per tender condition
216		Any specific Contractor Grade required as per CIDB to participate in this Bidding process? – Please clarify.	As per tender condition
217	Technical Specification (Kitchen Equipment) Page 549	The scope of work covered under this package comprises of Plan, Design, Supply, Installation, Testing and Commissioning of Kitchen equipment's complete - Kindly clarify whether designing is in our scope or not?	As per tender condition
218	Technical Specification (MGMS) Page 561	Complete Plan, Design, Supply, Installation, Testing and Commissioning including turnkey work and handing over of Medical Gases Manifold and Distribution System to the client. - Kindly clarify whether designing is in our scope or not?	As per tender condition

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
219	Specification - HMIS & PACS	<p>Roll out of existing HMIS (Hospital Management and Information System) & PACS (Picture Archival & Communication on System) for the new TEACHING Hospital: - Customization, Integration, Installation, Testing, Implementation, Commissioning & Training with 3 years maintenance support of the existing HMIS System of ENT Hospital in accordance with the requirements of the new teaching Hospital. - Implement existing HIMS product in new hospital- which is existing software (Name) - is it been completely deployed at ENT hospital ? its live there ? is the source code with client ? it to off the shelf product ? Interface PACS to HMIS software, - which is existing PACS software (Name) - is it been completely deployed at ENT hospital ? its live there ? QMS is part of scope - it is to be deployed only at New teaching hospital ? or at ENT hospital also ? what about the connectivity between both hospitals ? the solution deployed (HIMS) should talk to each other (centralized database is expected)? Education management software is mentioned for integration -is it deployed at ENT hospital or at teaching hospital ? PACS hardware is required only for new teaching hospital ?</p>	<p>The civil contractor of ENT Hospital can be contacted for these information</p>
220	Technical Specification _ HMIS	<p>Project Initiation Customization, Installation, Implementation, Integration and Maintenance of existing HMIS and Back office/ERP applications/system of the new ENT Hospital Mauritius in accordance with the requirements of the new TEACHING Hospital. Supply, Installation, Configuration, Testing and Commissioning of additional hardware for extending the HMIS & PACS applications of the ENT Hospital. - which HMIS?, does the institute own/have the complete source code and build mechanism for development?. Including the design document of the HMIS application? which PACS?, is the PACS customization is also part of our scope?</p>	<p>The civil contractor of ENT Hospital can be contacted for these information. The PACS customization is also part of the scope of work.</p>
221	Technical Specification _ HMIS	<p>Provide support and assistance for resolution of major Technical problems or Technical issues. (Teaching hospital will deal with a single vendor, who shall be a System Integrator Technology firm (hereinafter referred to as SI/Implementation Agency)) - Are we the SI ?.. if yes, who will do HMIS part?.. Will current vendor expected to continue to do the HMIS related work and we do SI/PM0 ?</p>	<p>SI is an IT firm who will be shortlisted as per terms of tender/contact. SI will execute all the IT works including HMIS. The running application of ENT Hospital will be deployed at new Flacq teaching hospital as per tender conditions.</p>
222		<p>It is the responsibility of SI to provide at least the following documents to client & HSCC: - Clarify Please.</p>	<p>As per tender conditions.</p>
223			
224	Technical Specification _ HMIS	<p>SI should ensure that HMIS application including back office application should be user friendly, interactive and easily understandable by the end users. The application should be used to make hospital paperless in all respect. These are parts of successful implementation of HMIS application and the mandatory part of this project. - if the expectation to roll out existing application stack, how can SI ensure this?.. whatever is there will get rolled out.. please get clarity on this.</p>	<p>This is not only a roll out project but also involves customization of applications as per the new Flacq Teaching Hospital requirement. Accordingly, the</p>

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
225	Technical Specification _ HMIS	Design Document incorporating System Requirement Specifications and Detailed Design & development of entire Application Software and its loading into the system. - Again, if this is rollout of existing HMIS, then what design document or SRS is expected and why?.. Don't they have it from current vendor who deployed the solution at the ENT hospital?	Teaching Hospital requirement. Accordingly these documents will be generated by SI and will have to be provided to client & HSCC.
226		The following functional modules and sub modules should be covered: - any of these modules not present with the current application?	
227		Drug Database that is to be provided with at least one year license should also have the - Which Drug DB ?.. like CIMS/MIMS ? which one is currently being used?	The civil contractor of ENT Hospital can be contacted for these information
228		Mobility - Existing functionality?	The civil contractor of ENT Hospital can be contacted for these information
229		Patient at home - Existing functionality and devices provided by hospital?	The civil contractor of ENT Hospital can be contacted for these information
230		All medications. (mother and child). - What medication we are referring here?	The civil contractor of ENT Hospital can be contacted for these information
231		Details of the necessary HW for PACS Server and workstation is mentioned below: - Which PACS?.. If it is existing how can we as SI provide FDA/CE/Other ACR certificates?	The civil contractor of ENT Hospital can be contacted for these information
232		All the licenses of the software will be provided in the name of the client, - How do we as SI provide license for application owned by other company ?	The civil contractor of ENT Hospital can be contacted for these information

**CONSTRUCTION OF TEACHING HOSPITAL AT FLACQ, MAURITIUS
PRE-BID QUERIES**

Sl. No.	Clause Ref. No.	Pre bid Query	Reply
233		SI shall be ready to make further customization / any changes as the need may arise from time to time during the above said period, without any extra financial cost. - This means ongoing development team attached to the project. There should be a ceiling number for the efforts included and what goes into CR.. Can you check with consultant and confirm?	User Acceptance and Final Acceptance Testing should be performed along with sign off hand over document.
234	General	In the tender Document many approved makes has been given for different kind of materials. - We are attaching herewith few approved makes. Kindly let us know if we can consider them for preparing our proposal.	As per tender condition
235	ITB C : Preparation of Bid, Page No. 17	Tender document to be submitted as per Annexure-X attached in the Volume-I. - But in Volume-I we didn't find the Annexure-X. Request you to provide us the same.	Annxure-x may be read as Annexure-VI
236	NIT and SCC/ITB/1.1.1 Page No. 12 & ITB Cl. 10.3 Page No. 18	As per NIT this is an ITEM RATE contract. Where as per SCC/ITB/1.1.1 complete design will be contractor's responsibility - Kindly clarify whether this is an ITEM RATE Contract or Design Built Contract.	Item rate contract
237	Retention Money	2% amount shall be deducted of monthly Invoice (Cash Retention). We request to consider this 2% also as BG Retention. - 2% amount shall be deducted of monthly invoice (Cash Retention). We request to consider this 2% also as BG Retention.	As per tender condition
238	GCC & SCC	We have found in the BOO that Prime Rate for Ceramic/Vitrified Tiles and Marble are given, where as there are no clause mentioned in the GCC and SCC for Price Escalation application to the project. Kindly clarify, whether Price escalation is applicable to this project or not. If yes what would be the modality of application of Price Escalation.	As per tender condition
239	SCC/37	Tax and duties are exempted. - We understand the this project is exempted from all kind of Taxes and Duties. Kindly confirm. Also clarify whether personal income tax applicable or not?	As per tender condition
240	SCC (Page 19) clause 12 and SCC Page No 96 Annexure D	As per specific Condition validity of Bid security is 180 days and it should be addressed to Deputy Permanent Secretary, Ministry of Health & Quality of Life, Government of Mauritius. Whereas as per bid Security format we found the validity of Bid security is 90 days and it should be addressed to HSCC(I) Ltd. - Kindly clarify this.	As per specific Condition validity of Bid and Bid security shall be 180 days
241	SCC (Page 19) clause 12 and SCC Page No 96 Annexure D	We have found all guarantee should be made on a Stamp Paper - As this is a International Contract, Can we submit Paper Guarantee instead of Stamp paper Guarantee.	As per tender condition