

AMENDMENT NO. -I

All Bidders.

Project Name: Tender for "Package-03, Supply, installation, testing & commissioning of Hostel Furniture for Hostel Block & other associated works and their maintenance during defect liability period for AIIMS at NCI Jhajjar, Haryana"

Tender No: HSCC/AIIMS-Jhajjar/Pkg-03/Hostel-Fur/2018, Dated: 07.05.2018

This has reference to the subject works.

The following **AMENDMENT-I/Clarification-I** may be noted, which shall be treated as a part of tender to be submitted online duly signed & stamp along with tender:

1. Clarification of pre bid queries enclosed at Annexure-I

All other terms & conditions of tender shall remain unchanged.

Prospective bidders are advised to regularly scan through HSCC e-tender portal <http://www.tenderwizard.com/HSCC> and <http://www.hsccltd.co.in> and as corrigendum /amendments etc, if any, will be notified on this e- tender portal only and separate advertisement separate advertisement will not be made for this.

(-Sd-)
Sr. Manager (Civil)
HSCC (India) Limited

Annexure-I

S. No.	Pre bid queries	Clarification
1	Package -03 (Hostel Furniture)	
2	BOQ Item No.1- Wooden Wardrobe –5 mm thick mirror as per drawing, please share drawing	As per Tender Conditions
3	<p>BOQ Item No. 2- Single Bed with Mattress – Please confirm width (W) 1524 mm (L) 1981 mm (H) 970 mm as per standard followed for single bed it should be W925 x L1925 x H690 mm.</p> <ul style="list-style-type: none"> - Please specify completely in MS or with wooden cladding ??? - Please specify with or without storage ??? - Specify mattress brand to standardize offering with 3 make at least 	<p>Single Bed of Size 900(W)X2050(L)X900(H) with Head Board and foot board. Head Board & Foot Board made up of 18 mm thick MDF with 0.4 mm membrane foil . Head board size: 900x600 mm and foot board of size: 900x300 mm Support structure of Bed made up of M.S. Pipe 75x25x1mm thick and 40x40x1.2mm thick duly powder coated through seven tank process of Powder Coating. Side Panel: - The side panels are made up of 18mm thick MDF Board with both side decorative laminate. All exposed edges are sealed with 2mm thick PVC edge Banding. Bed Base: - The Bed Base shall be made up of 12mm thick MDF Board with both side White laminate. All Exposed edges of MDF to be sealed with 2mm thick PVC edge band and 0.8mm thick PVC edge-band to be applied on Non-exposed edges with the help of hot-melt glue through fit edge-banding machines. The Edge-banding of exposed area to be done in the way that there should not be any sharp edge or corner left after processing. All the exposed edges should have buffing radius of 1.5 to 2mm without affecting aesthetic value of the panel. Mattress- Providing quilted mattress 4” with coir, Thickness of 100mm, density 80 GM/dcm³, pilled foam quilting (one side) 14 mm thickness, pilled foam density 18 GM/d cm³, PU foam thickness 5 mm, Fabric 85 GSM poly cotton material</p>
4	BOQ Item No. 3- Bed side Table – Body & drawer panel made of 18 mm thick PLPB. Please delete Side panels 18mm PLPB with imported HDF foil wrapped	As per Tender Conditions
5	BOQ Item No.8- Curtain Rod – 25 mm dia in SS, request to amend as MS powder coated used everywhere in projects and easily available. Also, define Rate per meter for the same.	As per Tender Conditions

6	BOQ Item No. 09- Curtain – Please specify brand, fabric thickness & rate in Sq meter.	This fabric in various colors, designs and patterns with rust proof SS eyelet 50 MM dia for hanging of curtains. The distance of each eyelet to be 8" of the next one. These should be wrinkle free made to measure eyelet curtains. Curtains to be provided with a 6" buckram fused into the top, high quality pressed steel eyelet to be inserted. Eyelet curtains will contain at least 1.5 time fullness. Curtain Material - Polyester Blended , Width 1.2 Mtrs.
7	BOQ Item No.10- Dustbin – Specify SS grade or MS. Mention Dia & height of dustbin, perforated or non-perforated	Dustbin- Dimension to be 8"X 12 ", Weight to be 0.850 KG, Material Non Magnetic SS 200 , Thickness 0.4 mm
8	BOQ Item No. 12- LCD TVs are outdated . it should be LED TV for 50" only smart TVs are coming . Hence Please clarify	LED Smart TVs 50"
9	BOQ Item No. 13. Flower Pot – Please specify Plastic / Metal / Clay with/without base plate to hold water. Size and Dia of flower pot.	Circular clay Flower Pot , with 14 inch height & 12 inch Dia., with Base Plate of Plastic
10	In machinery section you have asked for Computer Controlled multi station edge bending machine where as there is no such machine available kindly amend to manual machine	As per Tender Conditions
11	You have asked for BIFMA membership certificate only kindly amend to BIFMA Compliance	Bidder should have BIFMA Member with Bifma E3 Level Compliance certificate for furniture sustainability standard

All other specification remain same.