

AMENDMENT NO-I

Dated : 26.07.2022

PROJECT NAME Tender for “Construction of Blood Bank, Mortuary Bio-Medical Waste Management Room, Labs, Guest Rooms and associated works for AIMSS at Chamyana, Shimla, H.P.”

Tender No HSCC/AIMSS/HP/SHIMLA/ADD/2022/02, 04.07.2022

This has reference to subject work,the following Amendment may be noted which shall be treated as a part of the contract to be uploaded along with tender/bid:

Reply to Pre-bid queries raised by bidders, pre-bid meeting held on 18.07.2022 at HSCC, Head Office, Noida

SI NO	Ref.	Pre-Bid Queries/Bidder's Request/Description	Reply/Clarification/Amendment
1	Electrical Work & HVAC work	In tender list of approved make list of HSCC works, following makes for supply of electrical panel in serial. no. 30 (Tricolite/Adlec/Sterling &Wilson/ C&C/ Jackson Engineers/ Milestone/ Nitya/ SPC/ Risha/Neptune/ Zeta. However in tender list of appov. makes for electrical sysytem serial no.13, electrical panels only 4 makes are given from which it takes time to get quotes. Kindly allow all these other makes in electrical system also which are given for hvac works.	Approved make of Panels for HVAC & Electrical Works shall be as under : Tricolite/Adlec/Sterling &Wilson/ C&S/ Jackson Engineers/ Milestone/ Nitya/ SPC/ Risha/Neptune/ Zeta.
2	Vol 4 -Technical Specs, Approved Makes, HVAC Work	The name of Hvac vendors provided in the Tech. specifications are VOLTAS/BLUE STAR/SUVIDHA/UNIQUE ENGINEERS/ETA/STERLING&WILSON, however an undertaking is required to be provided for specialised agency as per the creteria laid down in form H of NIT. As the quantum of Hvac works is not too large the prescribed vendors in NIT may not get interested, thus we request you to delete the name of HVAC vendors	HVAC Subcontractors - VOLTAS/BLUE STAR/SUVIDHA/UNIQUE ENGINEERS/ETA/STERLING&WILSON mentioned in the List of Approved make for HVAC works stands deleted for this tender. However specialised agency should meet the criterion mentioned in Form H of Volume-I of Bid Documents.
3	Vol 4 -Technical Specs, Approved Makes, HVAC Work- Scroll chiller/Heat pump (S.No.3)	The makes for reversible Heat pump Carrier/ Trane/ York/ Danhum bush/ Mitsubishi, also it is to be inform that as per tender condition, Make in India machines are required to be installed, as these above companies does not make the heat pumps of the said rated capacity in India, we request you to review the conditions.	Additional make :- VOLTAS /BLUE STAR/ DAIKIN / KILOSKAR / CLIMAVENETA are also included. However if the machine is not manufactured in india by any vendor therefore class1, class2, class3, vendors shall be allowed as per DPIITmake in India guidelines.
4	SES (Special Services)	We request you to provide the makes of Boi medical Waste equipment's and Mortuary Sub Heads	Tender terms & conditions prevail.
5	Clause 10 CA , Volume - II, Bid Documents	Base price of all the materials covered under Clause 10CA (Base price to be mentioned valid at the time of last stipulated date of receipt of Tender including extension, if any.	Cement- OPC Rs. 5625/- per MT without GST
			Cement- PPC Rs. 5078/- per MT without GST
			Reinforcement Steel- Primary Manufacturer Rs.64000/- per MT without GST
6	Cement	We request you to allow PPC cementin the project.	OPC 43 cement/ PPC cement of approved make for both RCC & other works is allowed

All other terms & conditions of the tender shall remain unchanged.

Prospective bidders are advised to regularly scan through HSCC e-tender portal <http://www.tenderwizard.com/HSCC> & HSCC website <http://www.hsccltd.co.in>

GM (Projects)
HSCC (I) Ltd.