

AMENDMENT NO- 1

Dated-08.04.2022

PROJECT NAME Tender for "Up-gradation / Modification of existing Medical College, District Hospital & Construction of New Hospital Hostel blocks etc. for upgradation of Medical college at Churu, Rajasthan"

Tender No HSCC/MED/CHURU/PH-II/2022 dated 17.3.2022

This has reference to subject work, the following Amendment may be noted which shall be treated as a part of the contract to be uploaded along with tender/bid:

- 1 Reply to Pre-bid queries raised by bidders, pre-bid meeting held on 01.04.2022 at HSCC, Head Office, Noida

SI NO	Ref.	Pre-Bid Queries/Bidder's Request/Description	Reply/Clarification/Amendment
1	Civil Works	RMC plant outside ready mix concrete is allowed or not allowed?	Bidder shall install calibrated, computerised Batch mix plant of adequate capacity. In case of failure of Batching plant, outside ready mix concrete of approved manufacturer may be allowed as per approved design mix at no extra cost.
2	Civil Works	PPC Cement as per CPWD for both RCC & other works is allowed?	OPC 43 Cement/PPC Cement of approved make for both RCC & other works is allowed.
3	Availability of space	Can we use space within campus for setting up of Batching plant, temporary contractor office, Stores, workshops & Labour Camps etc.	Shall be as per Tender conditions. Bidder should visit and examine the site before submitting the bid. Spaces for batching plant, steel/shuttering yard, godown etc may be provided depending upon availability. The Bidder shall not have any claim whatsoever reason in case the space is not provided.
4	4.1.1. Approval Required Vol III (SCC)	The Payment of fees/Administrative expenses etc for approval/clearances etc shall be reimbursed based on documentary evidence as per actual, kindly clarify?	All the statutory expenditure incurred towards payment to the local body /authorities for getting statutory approval / clearances etc will be paid/reimbursed by owner on submission of proof of payment/deposition
5	41.0 (Clause 10C) Price variation-Vol III (SCC)	Please permit price variation payable after stipulated date of completion	Price variation shall be payable only upto stipulated date of completion. No price escalation shall be paid beyond that period.
6	Cl.no.32.7 (Temporary Fencing)-Vol-III (SCC)	We request you to kindly remove temporary fencing from the scope of contractor	Cl.no.32.7 (Temporary Fencing)-Vol-III (SCC) - Stands deleted.
7		Date of Submission may be extended for one week due to festival season.	Tender conditions prevails.

8	Civil works	Under approved make list Reinforcement steel - make SAIL,RINL & TISCO of Primary make is desired The Reinforcement steel is available in market of make JSPL,JSW & Essar are also of primary make parallel to SAIL,RINL & TISCO. Looking to above fact	Tender conditions prevails.
9	Civil works	Under approved make list the OPC -43 Grade Cement is desired.In present market PPC Cement of good quality is available and use of it is allowed in other similar projects.It is desirable that use of PPC cement may be allowed in this project please.	Please refer clarification at Sl. No. 2 .
10	Submission of Bid	The last date of Submission of Bid is 19.04.2022 14:00 hrs.To have a wide completion in this bid the last date of submission of this bid may be extended for further period of 15 days i.e. up to 05.05.2022 please.	Please refer clarification at Sl. No. 7.

All other terms & conditions of the tender shall remain unchanged.

Prospective bidders are advised to regularly scan through HSCC e-tender portal <http://www.tenderwizard.com/HSCC> & HSCC website <http://www.hsccltd.co.in> as corrigendum/amendments etc,if any,will be notified on this portal only and separate advertisement will not be made for this.

GM(Projects)
HSCC(India) Ltd.