

Ref- HSCC/LGBRIMH/Nurse-Hostel/Fur/2018

Dated: 17.04.2018

AMENDMENT NO. -I

**All Bidders.**

**Project Name: Tender for** "Supply, installation, testing & commissioning of Nurses Hostel & Auditorium furniture & other associated works and their maintenance during defect liability period at LGBRIMH, TEZPUR, ASSAM."

**Tender No.: HSCC/LGBRIMH/Nurse-Hostel/Fur/2018; Dated 27.03.2018**

This has reference to the subject works.

The following **AMENDMENT-I/Clarification-I** may be noted, which shall be treated as a part of tender to be submitted online duly signed & stamp along with tender:

Clarification of pre-bid queries enclosed at Annexure-I

Further, the last date of online fill/upload the tender has been extended as follows:

Last Date to fill/upload the tender through e-Tendering : **23.04.2018** up to 15:00hrs  
Date of opening of bids : **23.04.2018** at 15:30 hrs

The validity of Bid Security shall be considered from the original date of submission of bids. i.e. 17.04.2018

All other terms & conditions of tender shall remain unchanged.

Prospective bidders are advised to regularly scan through HSCC e-tender portal <http://www.tenderwizard.com/HSCC> and <http://www.hsccltd.co.in> and as corrigendum /amendments etc, if any, will be notified on this e- tender portal only and separate advertisement separate advertisement will not be made for this.

(-Sd-)  
Sr. Manager (Civil)  
HSCC (India) Limited

**Annexure-I**

<b>S.No.</b>	<b>Pre-bid queries</b>	<b>Clarification</b>
1	BOQ Item No. (02), sofa cum bed – the setting size required for sofa as 955 (D) is very high and will be uncomfortable for sitting. the standard depth for sitting shall be maximum 700mm. please confirm.	BOQ Item No. (02) Sofa: sitting depth 700 mm X backrest support 505 mm X total width 1520 mm X sitting height 340 mm.
2	BOQ Item No. (04), Bed side table- the specification mentions drawers please clarify if one or two drawers are to be provided.	BOQ Item No. (04) Bed side table, two Drawer shall be provided.
3	BOQ Item No. (08) Study Table. Wooden Drawer on both side with locking arrangement is required. please confirm the size of drawer required	BOQ Item No. (08) Study Table. Drawer size shall be 350mX150mmX575mm
4	<b>Vol-I, Pre-Qualification, Clause 3.3</b> <ul style="list-style-type: none"><li>- ISO- 9001-2008</li><li>- ISO- 14001-2004</li><li>- OHSAS- 18001</li><li>- BIFMA Membership Certificate.</li><li>- GREENGUARD/IGBC</li><li>- Computer controlled Multistation edge bending machine.</li><li>- Computer controlled Press brake for sheet metal bending.</li><li>- Converised powder coating plant.</li><li>- Hot Hydraulic Press Machine for laminate.</li><li>- Factory act license.</li><li>- PF registration</li></ul>	<b>Vol-I, Pre-Qualification, Clause 3.3</b> <ul style="list-style-type: none"><li>- ISO- 9001-2008</li><li>- ISO- 14001-2004</li><li>- OHSAS- 18001</li><li>- BIFMA Membership Certificate.</li><li>- GREENGUARD/IGBC</li><li>- Computer controlled Multistation edge bending machine.</li><li>- Computer controlled Press brake for sheet metal bending.</li><li>- Converised powder coating plant.</li><li>- Factory act license.</li><li>- PF registration</li></ul>

**All other specification remain same.**