

All Bidders**Amendment –I**

Project: Supply, Installation, Testing & Commissioning of LAUNDRY Equipment for Super Speciality Block at Indira Gandhi Medical College, Shimla ,H.P.

IFB No. HSCC/SES/Laundry/SSB/SHIMLA/2019 dated 21.02.2019

This has reference to above IFB.

The following Amendment may be noted which shall be treated as part of the tenders document and to be submitted duly signed & stamp along with tender.

Sr. No.	Bidders' Queries	Reply
1	<p>Sluicing Cum Washer Extractor</p> <p>a. 30 kg b. Soft Mount c. Door opening 500 mm Dia d. Final extract 870 rpm e. G Force 340</p> <p>Change requested</p> <p>a. 30 kg +/- 10% b. Rigid Mount c. 400 mm dia d. 800 rpm e. 300</p> <p>Benefit</p> <ul style="list-style-type: none"> • Rigid mount machines are suitable when mounting on Solid ground. They are cheaper than Soft mount machines. • Rigid mount machines have equivalent G Force and hence water extraction in washed fabric is high, while cost of machines is much less. Hence initial cost is saved. 	<p>Sluicing Cum Washer Extractor</p> <p>a. 30 kg +/- 10% b. Soft/Rigid Mount (With Vibration pad) c. Door opening 400-500 mm Dia d. Final extract 800-870 rpm e. G Force 300-340</p>
2	<p>Washer Extractor</p> <p>a. 30 kg b. Soft Mount c. Door opening 500 mm Dia</p>	<p>Washer Extractor</p> <p>a. 30 kg +/- 10% b. Soft/Rigid Mount (With</p>

	<p>d. Final extract 870 rpm e. G Force 340</p> <p>Change requested</p> <p>a. 30 kg +/- 10% b. Rigid Mount c. 400 mm dia d. 800 rpm e. 300</p> <p>Benefit Rigid mount machines are suitable when mounting on Solid ground. They are cheaper than Soft mount machines. Hence initial cost is saved.</p> <p>Rigid mount machines have equivalent G Force and hence water extraction in washed fabric is high, while cost of machines is much less. Hence initial cost is saved.</p>	<p>vibration pad) c. Door opening 400-500 mm Dia d. Final extract 800-870 rpm e. G Force 300-340</p>
3	<p>Washer Extractor</p> <p>a. Soft Mount b. Final extract 700 rpm c. G Force 320</p> <p>Change requested</p> <p>a. Rigid Mount b. 630 rpm c. 300</p> <p>Benefit Rigid mount machines are suitable when mounting on Solid ground. They are cheaper than Soft mount machines. Hence initial cost is saved.</p> <p>Rigid mount machines have equivalent G Force and hence water extraction in washed fabric is high, while cost of machines is much less. Hence initial cost is saved.</p>	<p>Washer Extractor</p> <p>a. Soft Mount/Rigid Mount (With Vibration Pad) b. Final extract 630-700 rpm c. G Force 300-320</p>
4	<p>Flat Bed Press</p> <p>Electric Load - 12/18 kW</p> <p>Change requested</p> <p>Electric Load - 12/18 kW Maximum</p>	<p>Tender terms & conditions prevail.</p>
5	<p>Aux Steam Generator</p> <p>Steam Capacity 10kg/h</p> <p>Change requested</p> <p>Steam Capacity 7kg/h</p>	<p>7 – 10Kg/h</p>

	Benefit	
	The steam requirement willnot be more than 4-6kg/hr.	
6	We would also like to request you to extend the due date to 29th March, 2019	Due date of submission is extended till 26.03.2019.

The bid submission date is extended from 19.03.2019 to 26.03.2019 and bid security should be valid for 180 days from the date of original bid submission ie. from 19.03.2019.
All other terms & conditions remain unchanged.

Sr. Chief General Manager -I, HSCC (I) Ltd.
For and behalf of Principal, IGMC, Shimla