

AMENDMENT No.- I

Project Name: Tender for “Up-gradation/ Modification of existing Medical College, District Hospital and Construction of New Hospital, Hostel Blocks etc. for Up-gradation of Medical College at Pali, Rajasthan”

Tender No. HSCC/MED/PALI/PH-II/2021/02 dated 07.01.2022

This has reference to subject work, the following Amendment may be noted, which shall be treated as a part of the contract to be uploaded along with tender/ bid:

(1) Reply to Pre Bid Queries raised by bidders, pre -bid meeting held on 18.01.2022 at HSCC, Head Office, Noida

Sl. No.	Ref. Cl. No. / Vol.	Pre-bid Queries / Bidder's Request / Description	Reply/ Clarification/ Amendment
1.		In tem No. 2. - Transformer, please add KIRLOSKAR make as it is a reputed Indian make and give quick delivery.	Shall be as per tender condition.
2.	Vol04_TechSpecs LIST OF APPROVED MAKES – Elect. Works	In item No. 3 - Main LT Panel please remove the make “SPC Electrotech” as all other makes are much bigger reputed International companies and then SPC make is not giving us correct prices as it seems it is supporting one particular bidder. If you can't remove this make, then also add few other small makes equivalent to SPC.	Authorized channel partner of Siemens/ABB/Schneider/ L&T/Legrand shall also be accepted.
3.		Item No. 12 - Similar problem in there C4S and Adlec (legrand) make don't quote us for these small items. Only 2 nos. local makes SPC & Tricolite are provided. Please add more makes. In your previous tenders many makes were for this item including Neptune / RISHA / Milestone etc.	Additional Make: Nitya Electro Control Pvt. Ltd./ Neptune/ Risha Control Engineers Pvt. Ltd.
4.	Vol04_TechSpecs(1) Page 1, LIST OF APPROVED MAKES - HVAC WORKS	Propeller Fans Make :- Crompton Greaves/ Khaitan/ Usha / Newtek/ Almonard / Havell's/Bajaj / Orient. Request to accept Kruger in approved make list for Propeller Fans. As we already in approved make list for Axial, Centrifugal and Inline Fans	Shall be as per tender condition.
5.	Vol04_TechSpecs, Specification, Page No- AC, Page 9 14.1 AXIAL FLOW FANS	As per specification “Straightening vanes shall be aerodynamically designed for maximum efficiency by converting velocity pressure to static pressure potential and minimizing turbulence.” BOQ mention Tube Axial Fan [(Vol05_BOQ (1) item No.1 5.3 5.4 BOQ Page No-Page Estimate- AC6-AC7)] and specification ask for straightening vane which means Vane Axial	Shall be as per tender condition.

Sl. No.	Ref. Cl. No. / Vol.	Pre-bid Queries / Bidder's Request / Description	Reply/ Clarification/ Amendment
		Fan, So Please confirm fan shall be Tube Axial or Vane Axial? However as per general practice Vane Axial fan are used for normal application & Tube Axial fan for Emergency application Please advise?	
6.	Vol04_TechSpecs Specification. Page No- AC, Page 9 14.1 AXIAL FLOW FANS	As per specification "The speed of fan shall not exceed 1000 RPM for fans with impeller diameter above 450 mm, and 1450 RPM for fans with impeller diameter of 450mm and less." Because the capacities are in wide range so optimum selections are not available at mentioned RPM, So request to accept the speed of fan not exceed 1450 RPM for fan with impeller diameter 1000mm or less and 1000 RPM for fan with impeller diameter above 1000mm.	Accepted
7.	Vol05_BOQ Item No.1 5.1 5.2 5.3 5.4/ BOQ Page No-Page Estimate- AC5-AC7 INLINE FANS/ PROPELLER FANS/ VENTILATION FANS	Certification of fan does not mention in tender. As you know that it is not feasible to check the performance of the fan at site, request you to mention AMCA certification (Truly AMCA - Interpolation not accepted) requirement for these fans in order to authenticate the performance of the fans.	Shall be as per tender condition.
8.	Civil Works:	RMC plant/ outside ready mix concrete is allowed or not allowed?	Bidder shall install calibrated, computerised Batch Mix Plant of adequate capacity. In case of failure of Batching plant, outside ready mix concrete of approved manufacturer may be allowed as per approved design mix at no extra cost.
9.	Civil Works:	PPC Cement as per CPWD for both RCC & other works is allowed?	For RCC Structural works – OPC 43 Grade only. For Other than RCC works – OPC 43 Grade / PPC.
10.	Availability of space	Can we use space within campus for setting up of Batching Plant, temporary Contractor Office, Stores, Workshops & Labour Camps etc.?	Shall be as per Tender conditions. Bidder should visit and examine the site before submitting the bid. Spaces for batching plant, steel/shuttering yard, godown etc. may be provided depending upon availability. The bidder shall not have any claim whatsoever reason in case the space is not provided.
11.	4.1.1. Approval Required - Vol.-III (SCC)	The Payment of fees/Administrative expenses etc for approval/clearances etc. shall be reimbursed based on documentary evidence as per actual. Kindly Clarify?	All the statutory expenditure incurred towards payment to the local body/Authorities for getting statutory approval/clearances etc. will be paid / reimbursed by owner on submission of proof of payment/ deposition.

Sl. No.	Ref. Cl. No. / Vol.	Pre-bid Queries / Bidder's Request / Description	Reply/ Clarification/ Amendment
12.	41.0 (Clause 10C) Price Variation - Vol.-III (SCC)	Please permit Price variation payable after stipulated date of completion.	Price variation shall be payable only upto stipulated date of completion. No Price escalation shall be paid beyond that period.
13.	Cl.No. 32.7 (Temporary Fencing) – Vol.-III (SCC)	We request you to kindly remove temporary fencing from the scope of contractor.	Stands Deleted
14.	BOQ - PLUMBING WORK - Vol.-V (BOQ)	Item no 10.00 [SEWAGE TREATMENT PLANT	Item no 10.00 SEWAGE TREATMENT PLANT (STP) - of Plumbing Work of BOQ - Item Description - “Note” has been amended & attached at Annexure –I .

All other terms & Conditions of the Tender shall remain unchanged.

Prospective bidders are advised to regularly scan through HSCC e-tender portal <http://www.tenderwizard.com/HSCC> & HSCC website <http://www.hsccltd.co.in> as corrigendum/amendments etc., if any, will be notified on this portal only and separate advertisement will not be made for this.

GM (Projects)
HSCC (India) Ltd.

ANNEXURE - I

Name of Work : Up-gradation/ Modification of existing Medical College, District Hospital and Construction of New Hospital, Hostel Blocks etc. for Up-gradation of Medical College at Pali, Rajasthan

Amendmend of PLUMBING WORK - BOQ item No. 10.00

S. NO.	DESCRIPTION		DESCRIPTION	
	As per BOQ		As Amendmend	
10.00	SEWAGE TREATMENT PLANT (STP)		SEWAGE TREATMENT PLANT (STP)	
10.01	<p>.....</p> <p>.....</p> <p>.....</p> <p>Note : The cost of chemical & mampower for trial run for period of two month from the date of handing over obtaining approval from Local Pollution Department including the cost of consumables complete as specification as directed Obtain required no. of test report of treated/raw sewer during trial run. No additional payment shall be made on this account.</p>		<p>.....</p> <p>.....</p> <p>.....</p> <p>Note : The quoted rate to include defect liability of three years as per contract. Civil work to be paid separately under respective civil work items. The cost of chemical & manpower for trial run for period of two month from the date of handing over obtaining approval from Local Pollution Department including the cost of consumables complete as specification as directed Obtain required no. of test report of treated/raw sewer during trial run. No additional payment shall be made on this account.</p>	