

**All Bidders****Amendment- II**

**Subject:** Execution including Design, Supply, Installation, Testing & Commissioning of Medical Gas Manifold System (MGMS) at National Institute of Mental Health and Neurosciences (NIMHANS), Bangalore, on Turnkey Basis

**References:** - 1. Tender No: HSCC/SES/MGMS/NIMHANS/2024/25, Dated 25.01.2024  
2. Pre Bid Meeting dated 01.02.2024

This has reference to above tender.

The following Amendment may be noted which shall be treated as part of the tender document and to be submitted duly signed & stamp along with tender :

Sr. No.	Bidder's Queries	Reply
1.	Page No. 4 of Technical Specifications of the Bid Document  Gas Outlet points  <b>Amendment Request:</b> We request you to incorporate the makes Active tech/ MR engg / Beacon	Tender terms & conditions prevail.
2.	Page No. 5 of Technical Specifications of the Bid Document  Isolation Valves  <b>Amendment Request:</b> We request you to incorporate the makes Leader	Tender terms & conditions prevail.
3.	Page No. 7 of Technical Specifications of the Bid Document  Horizontal Bed Head Panel  <b>Amendment Request:</b> We request you to incorporate the makes Active tech/ MR engg / Beacon	Tender terms & conditions prevail.
4.	Page No. 7 of Technical Specifications of the Bid Document  BPC Flowmeter with Humidifier  <b>Amendment Request:</b> We request you to incorporate the makes Active tech/ MR engg / Beacon	Tender terms & conditions prevail.

Sr. No.	Bidder's Queries	Reply
5.	<p>Page No. 8 of Technical Specifications of the Bid Document</p> <p>Ward Vaccum Unit</p> <p><b>Amendment Request:</b> We request you to incorporate the makes Active tech/ MR engg / Beacon</p>	Tender terms & conditions prevail.
6.	<p>Page No. 10 of Technical Specifications of the Bid Document</p> <p><b>Amendment Request:</b> Kindly clarify whether a copy of the CDSCO license needs to be submitted along with the technical bid</p>	Tender terms & conditions prevail.
7.	<p>Page No. 2 of Technical Specifications of the Bid Document</p> <p>Compressed Air System</p> <p><b>Amendment Request:</b> We request you to kindly specify the quantity of Medical Compressors</p>	Quantity of medical compressor shall be 2 or more as per standard.
8.	<p>Page No. 3 of Technical Specifications of the Bid Document: 3-stage Breathing Air Filters</p> <p><b>Amendment Request:</b> We request you to specify the numbers of 3-stage Breathing Air Filters, so that clarity remains among all the bidders</p>	2 Nos.  Tender terms & conditions prevail.
9.	<p>Page No. 3 of Technical Specifications of the Bid Document : Vaccum Pumps</p> <p><b>Amendment Request:</b> We request you to kindly specify the quantity of Vaccum Pumps</p>	Quantity of vacuum pumps shall be 2 or more as per standard.
10.	<p>Page No. 3 of Technical Specifications of the Bid Document : Vaccum Pumps of 36 CFM (min10 HP) capacity...</p> <p><b>Amendment Request:</b> If we consider minimum 10HP pumps, then the CFM is more than 36. Kindly clarify whether we should quote considering HP of pumps or CFM</p>	Min. 10 HP for each pump to be considered.

Sr. No.	Bidder's Queries	Reply
11.	<p>Page No. 3 of Technical Specifications of the Bid Document</p> <p>Vaccum Bacteria Filters</p> <p><b>Amendment Request:</b> We request you to kindly specify the quantity of Bacteria Filters</p>	<p>2 Nos.</p> <p>Tender terms &amp; conditions prevail and as per standard.</p>
12.	<p>Page No.11 of SCC of the Bid Document</p> <p>Manufacture Authorisation</p> <p><b>Amendment Request:</b> Kindly clarify whether Manufacture Authorisation Need to be submitted or not</p>	<p>Tender terms &amp; conditions prevail.</p>
13.	<p>Page No.5, Vol-1 , ITT</p> <p>Approval Required, if applicable import / manufacturing license from Central Licensing Authority or state licensing authority CDSCO license</p> <p><b>Amendment Request:</b> Kindly amend it as import / manufacturing license from Central Licensing Authority or state licensing authority CDSCO license</p>	<p>Tender terms &amp; conditions prevail.</p>
14.	<p>Page No.1, Technical Specification</p> <p>Oxygen System (Makes - Active tech/ MR engg / Beacon)</p> <p><b>Amendment Request:</b> Requested to add 'PES'</p>	<p>Tender terms &amp; conditions prevail.</p>
15.	<p>Page No.1, Technical Specification</p> <p>Automatic Oxygen Control Panel with changeover Alarm (Makes - Active tech/ MR engg / Beacon)</p> <p><b>Amendment Request:</b> Requested to add 'PES'</p>	<p>Tender terms &amp; conditions prevail.</p>
16.	<p>Page No.4, Technical Specification</p> <p>Gas Outlet Points (Makes - S Kumar/ med flow/ U made)</p> <p><b>Amendment Request:</b> Requested to add 'PES'</p>	<p>Tender terms &amp; conditions prevail.</p>

Sr. No.	Bidder's Queries	Reply
17	Page No.5, Technical Specification Isolation Valves (Makes - U flow/ Convex / AQ flow) <b>Amendment Request:</b> Requested to add 'PES'	Tender terms & conditions prevail.
18	Page No.5, Technical Specification Valve Box Assembly (Makes - Active tech/ MR engg / Beacon) <b>Amendment Request:</b> Requested to add 'PES'	Tender terms & conditions prevail.
19	Page No.6, Technical Specification Alarm System (Makes - Active tech/ MR engg / Beacon) <b>Amendment Request:</b> Requested to add 'PES'	Tender terms & conditions prevail.
20	Page No.7, Technical Specification Horizontal Bed Head Panels (Makes - S Kumar/ med flow/ U made) <b>Amendment Request:</b> Requested to add 'PES'	Tender terms & conditions prevail.
21	Page No.7, Technical Specification BPC flow meter with Humidifier (Makes - S Kumar/ med flow/ U made) <b>Amendment Request:</b> Requested to add 'PES'	Tender terms & conditions prevail.
22	Page No.8, Technical Specification Ward Vacuum Units (Makes - S Kumar/ med flow/ U made) <b>Amendment Request:</b> Requested to add 'PES'	Tender terms & conditions prevail.
23	Page No.10, Technical Specification It should have import/ manufacturing license from Central licensing Authority or state licensing authority of CDSCO for the product and copy of valid license should be submitted, if applicable	Tender terms & conditions prevails.

Sr. No.	Bidder's Queries	Reply
	<b>Amendment Request:</b> Kindly amend it as import/ Manufacturing / Registration from Central Licensing Authority or state licensing authority CDSCO license	The CDSCO registration is applicable to Class-A Non-Sterile/Non-Measuring Devices only. Valid license to be provided for the remaining items.

All other terms & conditions remain unchanged.

Prospective bidders are advised to regularly visit through HSCC e-tender portal <https://hsc.enivida.com> & HSCC website <http://www.hsccltd.co.in> as corrigendum/amendments etc. if any, will be notified on this portal only and no separate advertisement will be made for this.

( – sd – )  
 Chief General Manager  
 HSCC (India) Ltd.