

**All Bidders****Amendment -III**

Project: Supply, Installation, Testing & Commissioning of Modular Operation Theatres (MOTs) and Mid End Modular Operation Theatres at PGI Satellite Centre for PGIMER at Village Ghabdan, Sangrur.

IFBNo :HSCC/SES/MOT /PGI/SANGRUR/2019 Date : 11.01.2019

This has reference to above IFB.

The following Amendment may be noted which shall be treated as part of the tender document and to be submitted duly signed & stamp along with tender.

<b>Sr. No.</b>	<b>Bidders' Queries</b>	<b>Reply</b>
1	<p>Volume-III, SCC, Page no. 12, 12.3 Bid Security</p> <p>Document Fee and EMD are exempted for NSIC registered Firm.</p> <p>As you are aware, to promote Micro Small &amp; Medium Enterprise, Government of India had given the facility of NSIC Certification to the manufacturing firm. This may please be note that this clause is only applicable for manufacturing of goods in India and not for procurement of Imported goods.</p> <p>If we go through the tender BOQ items, most of the tendered items are Imported. The NSIC certificate will not be applicable, as the basic principal of NSIC Certification is goods Made in India.</p> <p>We have noticed that prominent bidders takes undue advantage of this clause. We request this clause should be further clarified that the Document Fee and EMD exemption is applicable to bidders registered with MSME for major value items (covering 50% value of the total upfront bid value of the tender). A declaration in this regard must be given along with the technical bid which</p>	<p>Document fee and EMD are not exempted for procurement of Imported goods.</p>

	<p>shall be verified upon opening of price bid. We are enclosing herewith Tender Paper of AIIMS clarifying the MSME Certification for your ready reference.</p> <p>We request this clause should be suitably amended so that NO Bidder could take undue advantage of NSIC/MSME Certification and all the bidders should be treated on single platform.</p>	
2	<p>Surgeon Control Panel - (Imported)</p> <p>Surgeon Control Panel is important item in Modular Operation Theatre. For Authentication and genuiness of the product Surgeon Control Panel should be European CE with 4 digit notified no. / USFDA.</p>	<p>Surgeon Control Panel should be European CE with 4 digit notified no. / USFDA</p>
3	<p>Specs-OT AC-Page 1 to 44</p> <p>Detailed Specifications System Design Data, Air Handling Units (sectional Type) etc.</p> <p>As per Amendment no. II dated 14.02.2019, the Department has removed the Makes of the tender.</p> <p>Kindly clarify that the mentioned makes at page no. Specs - OT-Page -41 to 44, also stands deleted.</p>	<p>Specs-OT AC-Page 1 to 44</p> <p>Detailed Specifications System Design Data, Air Handling Units- AHUs (sectional Type) etc.</p> <p>The mentioned makes at page no. Specs - OT-Page -41 to 44 for AHUs shall prevail and not deleted.</p>
4	<p><b>Technical Specifications of Minor OT</b></p> <p><b>Swing Doors- Double leaf Door SS-304</b></p> <ol style="list-style-type: none"> <li>1) Please note Clean room doors can only be open from one side instead of both the sides for Minor OT's because frames of Doors are made of extruded aluminium which don't allow both side opening. You are therefore requested to kindly amend and mention " One side opening instead of both ways opening".</li> <li>2) Double skinned SS-304 sheets with thickness of 0.6mm instead of 0.8mm thick. Please amend the same to 0.6-0.8mm thick SS-304 sheet.</li> <li>3) Door frames are made of 2.5mm</li> </ol>	<ol style="list-style-type: none"> <li>1) Tender terms and conditions prevail.</li> <li>2) Thickness of sheet 0.6- 0.8 mm.</li> <li>3) Al/GPSP of thickness 2.5/1.2mm.</li> <li>4) 5/6 mm thick. Material for glass should be tempered/float glass.</li> <li>5) Colour of door shall be fixed to SS finished door.</li> </ol>

	<p>thick anodized aluminium 6063 T6 instead of GPSP Powder Coated. Please amend the thickness of Door frame from 1.2 mm to 2.5 mm thick.</p> <p>4) View Panels- it will be 5mm thick tempered glass instead of 6mm thick float glass since tempered glass are hardened and high quality glass sheet specially designed for use in Hospital / Healthcare purpose. We therefore request you to kindly amend materials of glass to tempered/float glass.</p> <p>5) Since you had asked for SS-304, color of door will be fixed to SS finished door only. Please amend the same.</p>	
5	<p><b>Technical Specifications of Minor OT</b></p> <p><b>Hinged Doors- Single leaf Door SS-304</b></p> <p>1) Double skinned SS-304 sheets with thickness of 0.6mm instead of 0.8mm thick. Please amend the same to 0-6-0.8mm thick SS-304 sheet.</p> <p>2) Door frames are made of 2.5mm thick anodized aluminium 6063 T6 instead of GPSP Powder Coated. Please amend the thickness of Door Frame from 1.2mm to 2.5mm thick.</p> <p>3) View Panels- it will be 5mm thick tempered glass instead of 6mm thick float glass since tempered glass are hardened and high quality glass sheet specially designed for use in Hospital / Healthcare purpose. We therefore request you to kindly amend Material of glass to tempered/float glass.</p> <p>4) Since you had asked for SS-304, color of door will be fixed to SS finished door only. Please amend the same.</p>	<p>1) Thickness of sheet 0.6- 0.8 mm.</p> <p>2) Al/GPSP of 2.5/1.2mm.</p> <p>3) 5/6 mm thick. Material for glass should be tempered/float glass.</p> <p>4) Colour of door shall be fixed to SS finished door.</p>
6	<p><b>Prequalification Criteria – Regarding Similar Experience</b></p>	<p>1) Tender terms and conditions prevail.</p>

	<p>1) In Amendment No. II, regarding similar nature of work, it is mentioned that SITC of Modular Operation Theatres &amp; AHU in India – We would like to submit that AHU’s are not part of Modular OT and neither in any work of MOT allotted by HSCC in past has this clause. We therefore request you to kindly delete the word “&amp; AHU’s” from similar nature of work and mention “SITC of Modular OT’s in India” only.</p> <p>2) Please refer to point no. 21 of Amendment No. II, regarding Experience of private sector, the order issued by private sector is in two parts, ie. first part is called Supply Order for Supply of Materials and Second part is called Work Order for Labor and installation work and TDS is only applicable on work order and not on supply order value. Hence you are requested to kindly amend the experience clause for private sector and mention, in case of private work, bidder should submit LC document/CA certificate certifying the total amount of work carried out by bidder and payment received.</p>	<p>2) In case of private work, bidder should submit TDS Certificate/LC document certifying the total amount of work carried out by bidder and payment received.</p>
7	<p>Further the time provided for uploading the tender is very short and is not sufficient since tender contains imported items. We therefore request you to kindly upload the above required technical amendment at the earliest along with extension for another 10-15 days to make it easier for us to submit our bid on time.</p>	<p>Tender is extended till 28.02.2019.</p>

**The bid submission date is extended from 25.02.2019 to 28.02.2019 and bid security should be valid for 180 days from the date of original bid submission ie. from 07.02.2019.**

All other terms & conditions remain unchanged.

Sr. Chief General Manager -I, HSCC (I) Ltd.  
For and behalf of Director, PGIMER, Chandigarh