

All Bidders

Amendment – III

Subject: “Establishment of Local Area Network (LAN) and Queue/Token Management System for Temporary OPD at AIIMS, Raibareli (UP)”

Tender No- HSCC/IT/Temp-OPD/Raibareli/2014 dated 15/02/2014

Dear Sir,

Bidders are requested to note that:

(1) Volume IV, Bill of Quantities (Sr. No.5.0) Page No 3-4

Item	As per tender	Amendment
UPS SYSTEM	<p>UPS Panel</p>	Deleted
	<p>Supply, installation, testing and commissioning of following M.V. cubicle type totally enclosed, wall mounted type, powder coated, dust, damp and vermin proof, indoor type Distribution Board/Panel complete with busbars, M.V. danger notice plate, interconnections with suitable capacity aluminium leads/solid aluminium strips/rods, connection of incoming and outgoing cables with thimbles, and having following incoming and outgoing switchgears complete as per technical specification and as required.</p>	
	<p>a) INCOMER:</p>	
	<p>100 Amps,415 volts, FP 35 KA Moulded Case Circuit Breaker with thermal magnetic release having variable current settings .</p>	
	<p>R,Y&B phase indicating lamp (LED type) with 6A control SP MCB.</p>	
	<p>ON,OFF TRIP indication for MCCB with 6A control SP MCB.</p>	
	<p>1 No. 0 to 500 V Digital voltmeter with selector switch.</p>	
	<p>Digital ammeter with selector switch with one set of suitable C.Ts.</p>	
	<p>b) BUSBARS:</p>	
	<p>100 Amp TPN Aluminium busbars</p>	
	<p>c) OUTGOING:</p>	
	<p>i) 2 no.63 Amps , 415 volts, 9 KA ,Four Pole, Miniature Circuit Breaker, with ON/ OFF indication.</p>	
<p>ii) 4 no. 32 Amps , 240 volts, 9 KA ,Double Pole, Miniature Circuit Breaker, with ON/ OFF indication.</p>		
<p>iii) 4 no. 40 Amps , 240 volts, 9 KA ,Double Pole, Miniature Circuit Breaker, with ON/ OFF indication.</p>		

Please note that this one no. 20 KVA UPS is to be supplied without UPS Panel. Other Specifications of the UPS will remain the same.

(2) Volume IV, Bill of Quantities (Sr. No.4.4) Page No 2

Item	As per tender	Amendment
Server Hardware	Supply, installation, testing and commissioning of latest Server Hardware as per the technical specification mentioned (Make - HP/Dell/IBM) as per the requirement & complete in all respect and as directed to the satisfaction of engineer	Supply, installation, testing and commissioning of latest Server Hardware as per the technical specification mentioned (Make - HP/Dell/IBM) as per the requirement & complete in all respect and as directed to the satisfaction of engineer. Server hardware to be supplied along with 1 no. latest Antivirus software (Server Edition) (Make - Quick heal/Norton/ McAfee) for one year subscription/validity .

The above Amendments shall be treated as a part of the contract to be submitted duly signed & stamp along with tender envelop no. – 2.

All other terms & conditions of tender document shall remain unchanged.

Prospective bidders are advised to regularly scan through HSCC web site as corrigendum/amendments etc., if any, will be notified on HSCC web site and separate advertisement will not be made for this.

Thanking you,

Yours faithfully,

(A K Nema)
Senior Manager (System)