## All Bidders

## Amendment -V

Project: Supply, Installation, Testing & Commissioning of Medical Gas Manifold System for PGI Satellite Centre, Sangrur, Punjab.

IFB No : HSCC/SES/MGMS/PGI/SANGRUR/2019 Date : 09.01.2019

This has reference to above IFB.

The following Amendment may be noted which shall be treated as part of the tenderdocument and to be submitted duly signed & stamp along with tender.

| Sr | Bidders' Queries  | Reply   |
|----|---|---|
|    |   | 1.7   |
| No |   |   |
| •  |   |   |
| 1  | We would like to highlight regarding Anesthesia Gas<br>Scavenging System (Imported). There is only<br>onetechnology i.e. Rotary Vane mentioned in NIT specs<br>whereas HTM/ISO allows "Blower"technology which is<br>also Oil Free produce better output with less energy<br>consumption. | AGSS should be provided<br>as per NFPA-99c/HTM-<br>02-01/ISO -7396-<br>1/DIN/EN                 |
|    | Requestyou to please add "Oil Free Blower<br>Technology".So, request you to please allow AGSS system<br>technology as per relevant standards.   |   |
|    |   |   |
| 2  | We request the Tender Submission Date may please be   | Tender submission date is extended till 08.03.2018.   |
|    | extended from 28.02.2019 to 08.03.2019, as arrangement<br>of Authorisation Letters  | extended till 08.05.2018.   |
|    | and best competitive price from Foreign   |   |
|    | Principal/Manufacturer will take some more time.  |   |
|    |   |   |
|    | We request to please extend the Tender Submission Date to 08.03.2019.   |   |
| 3  | Ref. Pre-qualification Criteria - Regarding Similar<br>Experience - Ref. To the amendment issued, we would<br>like to mention that we have executed one order through<br>Ahluwalia Contract Ltd. for HSCC project, who is one of<br>the customers of HSCC (India) Ltd. We would like to   | As per Amendment III<br>In case of private work,<br>bidder should submit<br>TDS certificate /LC |
|    | mention that the customer has not deducted TDS on   | document certifying   |

|   | supply order and TDS was only deducted on the<br>installation part. In HSCC projects, none of the customer<br>open LC document, hence it is not possible for us to<br>submit LC document as evidence to proof receipt of<br>payment in private work. We therefore request you to<br>kindly consider and add "CA Certificate certifying total<br>amount of work carried out and payment received". | total amount of work<br>carried out by bidder and<br>payment received. –<br>Deleted. |
|---|---|--|
| 4 | Further we once again request for extension of time for<br>minimum10-15 days from the date of uploading of<br>suitable corrigendum to enable us to submit our bid on<br>time.   | Tender submission date is extended till 08.03.2018.                                  |

All other terms & conditions remain unchanged.

Sr. Chief General Manager -I, HSCC (I) Ltd. For and behalf of Director, PGIMER, Chandigarh