All Bidders

Amendment -V

Date: 20.05.2019

Project: Supply, Installation, Testing & Commissioning of Modular Operation Theatres for Hospital Block, All India Institute of Medical Sciences (AIIMS), Raebareli.

IFB No. HSCC/SES/MOT/AIIMS/Raebareli/2019 dated 29.03.2019

This has reference to above IFB.

The following Amendment may be noted which shall be treated as part of the tender document and to be submitted duly signed & stamp along with tender.

S.No	Bidders' Queries	Amended as	
1	<u>Item no. 12B</u>	1.2 mm thick GPSP	
		powder coated door	
	1.2 mm thick GPSP powder coated door frames/2.5 mm	frames/2.5 mm thick	
	thick anodized aluminium 6063 T6.	Powder	
	TIT	coated/anodized	
_	We request this should be powder coated/aluminum.	aluminium 6063 T6.	
2	Item No.18B	Item No.18B	
	HD Flat Panel Monitor	HD Flat Panel Monitor	
	It should be Medical Grade Class-1 Device and European	should be	
	CE Declaration of Conformity to be provided.	USFDA/European CE	
	Please note,	certified	
	Class I medical device are those devices that have a low		
	to moderate risk to the patient and/or user. Today, 47%		
	of medical devices fall under this category and 95% of		
	these are exempt from the regulatory process.		
	Item no.19		
	Monitor Digital Display (PACS/HMIS)	Item no.19	
	It should be Medical Grade Class-1 Device and European	Monitor Digital	
	CE declaration of Conformity to be provided.	Display (PACS/HMIS)	
		should be	
		USFDA/European CE	
		certified	

3	Item no. 20	Item no. 20
	Anaesthesia and Surgeon Pendant Pendant should have Brake Light. The brake light will have deviating affects as the light will always be on/off. Even when the surgeon is performing surgery, the light will on/off will divert the attention. We therefore request pendant brake light should be deleted.	Anaesthesia and Surgeon Pendant Brake light deleted
4.	Regarding Manufacturer Authorization It is requested to Kindly amend the same and mention Manufacturer Authorization for below items to be submitted: 1) OT Light with HD Camera 2) HD Flat panel Monitor 3) Recording System 4) Touch Screen Control Panel 5) Monitor – Digital Display (PACS/ HMIS) 6) Pendants for Anesthetist and Surgeon 7) Isolation Transformer 8) Laminar Air Flow System For most of the items authorization letter is required, but such a important item of Modular Operation Theatre i.e. Wall & Ceiling System (SMS) is not asked. We request authorization letter of Wall & Ceiling System (SMS) should be asked.	Manufacturer Authorization for Wall & Ceiling System should also be provided by bidder in addition to other authorization as asked in tender/Amendment.
5	Item-7 Touch Screen Control Panel The Control Panel shall work as control panel should work as the central control panel for the HVAC controls, Touch Screen, ON/OFF Operation of OT light. Kindly delete word Instruction Board from the specification	Tender terms & conditions prevail
6	Double Leaf Door 40mm thick doors made with 0.6-0.8mm thick double skinned SS-304 sheets on both sides with PUF as infill. Wall frame in SS of 2mm thick. The Hinges are SS-304 with 2 way spring action etc. Supply & installation of double glazed view panes (Size	40-44 mm thick doors made with 0.6-0.8mm thick double skinned SS- 304 sheets on both sides with PUF as infill. Wall frame in SS of 2mm

7	300mm x 300mm), with 5 mm thick tampered glass with necessary arrangements. View Window The window blinds should be operated with Remote Control Since you had asked for motorized blinds, hence Manual operations are not possible. Kindly delete the word Manually from tender specifications.	thick/1.2 mm thick GI powder coated. The Hinges are SS-304 with 2 way spring action etc. Supply & installation of double glazed view panes (Size 300mm x 300mm), with 5 mm thick tampered glass with necessary arrangements. Tender terms & conditions prevail
8	Online Central UPS We request you to kindly provide OT Complex Drawing with OT Room and UPS Room making in the drawings to enable us to quote as per your requirement. Since online UPS is very costly equipment, hence indicative rates cann't be quoted in tender based on assumptions	Tender terms & conditions prevail
9	Item No.24-Turnkey works In the item description, this item is given but quantity is not mentioned in the BOQ. It seems you missed out to add/mention the quantities in tender BOQ. You are requested to kindly mention the same.	Tender terms & conditions prevail
10	Laminar Air Flow System Since you had asked for specific Authorization for Laminar Air Flow System, Please clarify, if you require indigenous or imported wall and ceiling system.	Tender terms & conditions prevail
11	Wall and Ceiling Panel Since you had changed wall and Ceiling to be of imported make, we request you to kindly add Sub frame, Wall and ceiling system. Further kindly add Sub Frame, Wall Panels, Angular Extraction Module, Sealing Gaskets, Ceiling Panels should be of same make, Manufacturer and Country of Origin.	Read as Wall and ceiling system with Sub frame. Wall and ceiling system, Sub frame and Sealing Gaskets must be of same manufacturer.
1.0	As per BOQ of tender: Total MOT-13 Nos Area of Wall = 1917Sq.m Area of Ceiling Panel =660 Sq.m Area of floor = 710 Sq.m	Amended as: Total MOT-13 Nos Area of Wall = 1305Sq.m Area of Ceiling Panel =762Sq.m Area of floor = 838 Sq.m Revised BOQ attached
2.0	Date of extension of another 10-15 days from the date of uploading of suitable corrigendum	Extended to 27.05.2019

The bid submission date is extended from **22.05.2019 to 27.05.2019** and bid security should be valid for 180 days from the date of original bid submission ie. from 29.04.2019.

All other terms & conditions remain unchanged.

Sr. Chief General Manager -I, HSCC (I) Ltd. For and behalf of Director, AIIMS, Raebareli