

All Bidders

Amendment –VIII

Project: Supply, Installation, Testing & Commissioning of Medical Gas Manifold System for Super Speciality Block at Indira Gandhi Medical College, Shimla, H.P.

IFB No. HSCC/SES/MGMS/SSB/Shimla/2019 dated 31.01.2019

This has reference to above IFB.

The following Amendment may be noted which shall be treated as part of the tender document and to be submitted duly signed & stamp along with tender.

Sr. No.	Bidders' Queries	Reply
1	<p>Tech. Spec.-Page 11</p> <p>10.0 Area Valve Service Unit (Imported)</p> <p>Please refer to the Amendment –VI dated 26.03.2019, it is mentioned that product should be USFDA/European CE 4 digit notified body number or American ETL</p> <p>We would like to clarify that American UL or ETL certification does not come with Area Valve Service Unit. At the time of execution of the project , bidder who follows NFPA -99 Standard, will not be able to provide this certification. Earlier AVSU was Indigeneous, it is only as per Amendment VI dated 26.03.2019, the item is amended.</p> <p>We request the Area Valve Service Unit should remain Indigeneous, when Quality product is available in India and preference now a days is given to Indian Manufacturer/product. Area Valve service certifications should be CE.</p>	<p>Product should be provided as per HTM 02-01/NFPA 99C/DIN/EN/ISO-7396-1 standards.</p>
2	<p>It is our humble request to kindly extend the tender submission date up to 09.04.2019, enabling us to submit competitive offer.</p>	<p>Tender submission date is extended up to 09.04.2019.</p>

The bid submission date is extended from **04.04.2019 to 09.04.2019** and bid security should be valid for 180 days from the date of original bid submission ie. from 27.02.2019.

All other terms & conditions remain unchanged.

Sr. Chief General Manager -I, HSCC (I) Ltd.
For and behalf of Principal, IGMCM, Shimla