

All Bidders**Amendment –X**

Project: Supply, Installation, Testing & Commissioning of Medical Gas Manifold System for Hospital Block, All India Institute of Medical Sciences (AIIMS), Raebareli.

IFB No. HSCC/SES/MGMS/AIIMS/Raebareli/2019 dated 29.03.2019

This has reference to above IFB.

The following Amendment may be noted which shall be treated as part of the tender document and to be submitted duly signed & stamp along with tender.

S.No	Bidders' Queries	Amended as
1	<p>Pg. 16 of Vol. IV Technical Specifications</p> <p>8. AGSS (Anesthetic Gas Scavenging System) Plant</p> <p>The package should consist of two dry rotary vane/Claw type vacuum pumps (dry/oiless only), a control panel and mounted on a common base frame.</p> <p>It is requested that recent tender of AIIMS and PMSSY IV (HITES/PCD/PMSSY-IV/02/MGPS/18-19 dated 14.02.2019) attached for your reference. They have included blower type as well since HTM and ISO allow blower type to be used in AGSS.</p> <p>Therefore , we request that blower type be included as well.</p>	<p>AGSS should comply with standards mentioned in the technical specification.</p>
2	<p>Amendment VII dt. 27.05.2019</p> <p>Sr. No. 8</p> <p>Minimum 20 TR AC (ductable with exhausts) will be considered for ranking purpose and price to be quoted separately.</p> <p>It is requested that revised BOQ does not have the line item for 20 TR AC. Request you to amend the BOQ to include the same.</p>	<p>Minimum 20 TR AC (ductable with exhausts) will be part of Turnkey works .</p>

All other terms & conditions remain unchanged.

Sr. Chief General Manager -I, HSCC (I) Ltd.
For and behalf of Director, AIIMS, Raebareli