

Amendment -II

Subject: **Supply, Installation, Testing & Commissioning of Medical Gas Pipe Line (Manifold)System at Cantonment General Hospital, Delhi Cantt.**

Tender No. DCB/H/TN/MGMS/29/2014

This has reference to the Pre-bid meeting held on 27.08.2014 at Cantonment General Hospital, Delhi Cantt. for the above tender of the Subject works.

The following Amendment may be noted which shall be treated as part of the contract to be submitted duly signed & stamp along with tender.


Sl. No.	Existing Clause/Specification	Amended clause/Specification
1.	Clause 14.2 on page no.4 The bid security and cost of document shall be in the form of a Demand Draft/ Banker's cheque from a Nationalized/Scheduled bank payable at Delhi.	The bid security and cost of document shall be in the form of a Demand Draft / Banker's cheque /Bank Guarantee from a Nationalized/Scheduled bank payable at Delhi.
2.	Point no.4 of Section-III, page no. 23 The entire project has to be done on turnkey basis including internal civil, water piping, plumbing and electrical works including water softening. Any minor details of construction which are obviously and fairly intended or which may not have been definitely referred to in this contract but which are usual of construction practice and essential to the work shall be included in this contract.	Plant Room and Manifold Room with electrical power supply will be provided by the Cantonment General Hospital.
3.	Point no. 14 of Section-III,page no.24 The bidder must have dealership/distributorship from the same manufacturer (whose manufactured items are offered in the bid) at least one year from the last day of the month previous to the one in which tender is invited.	The bidder must have dealership/ distributorship from the same manufacturer, whose manufactured items (Imported products only) are offered in the bid, at least one year from the last day of the month previous to the one in which tender is invited.

Mujr
12/9/14 *Qd*
12/9/2014 1

4.	PointNo.12.1 on page no.46 Flow meter with Humidifier(Imported) CE Marked	Flow meter with Humidifier (Imported) shall be CE Marked/ UL Listed/USFDA.
5.	PointNo.12.2on page no. 47 Ward Vacuum Units (Imported) CE Marked	Ward Vacuum Units (Imported) shall be CE Marked /UL Listed/USFDA
6.	PointNo.12.3on page No.47 Theatre Vacuum Units (Imported) CE Marked	Theatre Vacuum Units (Imported) shall be CE Marked/ UL Listed/USFDA
7.	PageNo.73 Manufacturer's Authorization incase the bidder is not the manufacturer.	Tender terms prevail
8.	PageNo.74 Third party quality certification of the MGMS equipment from SGS/TUV/Lloyds should be submitted as "Certifies that the MGMS equipment meets the technical specification and BOQ of the tender document".	Tender terms prevail.

noja
12/9/14 *Das*
12/9/2014

9.	As per Point No. 14.2 (Section I)The bid security shall be inform of Demand Draft /Banker's Cheque from a Nationalized bank.	As per Sl.No.1
10.	As per Point No.14 (Section III- Additional Specific Condition of Contract): The bidder must have dealership / distributorship from the same manufacturer at least from one year.	As per Sl.No.3
11	<p>a) Manifold &Emergency Manifold System</p> <p>The complete tender specifications of the items of the Medical Gas Pipeline System are company specific. The main manifold and emergency manifold specifications are totally different. The main manifold states that it should comply as per HTM02-01/C 11but the emergency manifold states that it should be certified from Lloyd's only" with its certified no .088 mentioned in the TE. It is a company specific certification. Also, there are other certifying agencies like TUV, SGS etc then why their no. is not mentioned.</p> <p>b) Manifold &Emergency Nitrous Oxide Panel</p> <p>The complete specifications and certification are company specific as explained above</p> <p>c) Fully automatic Control Panel for Nitrous Oxide</p> <p>The complete specifications and certification are company specific as explainedabove</p> <p>d) Medical Compressed Air Supply System</p> <p>The compressor stated in the TE documents only the oil injected screw compressor only. The details mentioned in the medical air supply are again company specific. The oil-free compressors based on reciprocating technology is not permitted</p> <p>e) Medical Vacuum Supply System</p> <p>The Vacuum pump specification gives range between</p>	<p>The design & selection of all imported items should be of international standard like NFPA 99 (latest version) standard and UL listed or DIN EN (latest version) and UL listed/CE marked or as per HTM 02-01guideline (latest version) and CE marked.</p> <p>This supersedes single/multiple standards/guideline mentioned at any other places in the tender specification involving item/system/capacity etc.</p> <p>The imported products should be of one standard/Guideline only. All indigenous items should be of high quality and compatible to the main system.</p> <p>The word "Pyrex", "GEM10"or if any other company specific brand/model mentioned in the tendered specification is hereby deleted.</p> <p>Certification shall be required from Lloyds/SGS/TUV instead of any single name mentioned in the tendered specification.</p>



 12/9/14

 12/9/2014 3