

Dated- 04.01.2014

Amendment No.-1

Project Name: Construction of Temporary OPD, Guest House & Boundary Wall for PGI Satellite Centre at Sangrur, Punjab

TENDER NO.: HSCC/PGI/Sangrur/2013

Reply of Bidders's queries raised during Pre-bid meeting held on 31.12.2013 at HSCC, Head office, Noida (UP):-

S.No.	Queries	Reply
1.	Kindly Limit the Performance Guarantee to 2.5%	As per terms & conditions of the tender documents.
2.	Kindly make security deposit as Bank Guarantee instead of cash	As per terms & conditions of the tender documents.
3.	Quantity of Concrete is not enough for batching plant. The distance between the both buildings is also more. We propose to use Gamzen mixer with Pump.	As per terms & conditions of the tender documents.
4.	There is no RMC plant in the vicinity. This item will also be done as above.	As per terms & conditions of the tender documents.
5.	Item No. 3.06 of steel reinforcement states up to plinth level. There is no item for steel reinforcement above plinth level.	Amended BOQ item No 3.06 is attached at Annexure-I
6.	Civil Contractors are exempt for ESI. The notification is attached herewith. Our rates would be without it.	To be complied as per ESI act
7.	Kindly provide the flooring details.	Flooring work shall be carried out as per respective BOQ item. However other details shall be provided during execution of work
8.	Should we sign& scan the documents for online submission.	Upload the documents on e- portal through digital signature
9.	Clause No.1.4- Eligibility Criteria No. of Stories of RCC work (multistoried Framed Structure) may be clarified	Clause no 1.4 Vol-I, similar works shall be read as a Project comprising Construction of any multistoried RCC framed structure of height 15 metres above ground level or multistoried RCC framed structure having more than 4 stories above ground level (basement, machine room and mumty) shall not be counted as a storey) including internal plumbing & electrical works.
10.	Signage Quantities are very large & Please Check the quantity of item no. 10.06 of sub head miscellaneous in civil work, qty given is 10000, which seems to be wrong	Amended BOQ item no 10.06 is attached at Annexure-I

32. **Only amended Bill of Quantity (volume V of tender documents), which have been uploaded on HSCC e-tender portal <http://www.tenderwizard.com/HSCC>, shall be used for quoting of rates by bidders.**

All other terms and conditions of the tender shall remain unchanged.

Prospective bidders are advised to regularly scan through HSCC e-tender portal <http://www.tenderwizard.com/HSCC> as corrigendum/amendments etc., if any, will be notified on this portal only and separate advertisement will not be made for this.

(-Sd-)

**General Manager (Projects),
HSCC (India) Ltd
(For & on behalf of PGIMER Chandigarh)**

Annexure-I

Amendment for BOQ (Civil)

As per Tender				As per Amendment		
Tender Item no.	Item	Qty	Unit	Item	Qty	Unit
3.06	Steel reinforcement for R.C.C. work including straightening, cutting, bending, placing in position and binding all complete upto plinth level.			Steel reinforcement for R.C.C. work including straightening, cutting, bending, placing in position and binding all complete for all levels.		
	Thermo-Mechanically Treated a) bars	600252	Kg	Thermo-Mechanically Treated bars	600252	Kg
10.06	Providing, fabricating and fixing of LED signages made from acrylic 2 sheets + LED strips & power supply in size of 3'x4' with the message print out and stainless steel studs on the walls including cost of screws and fixing complete as per directions of engineer.	10000	each	Providing, fabricating and fixing of LED signages made from acrylic 2 sheets + LED strips & power supply in size of 3'x4' with the message print out and stainless steel studs on the walls including cost of screws and fixing complete as per directions of engineer.	8	each