

Clarifications (Electrical) towards query raised by different bidders during pre-bid meeting of Hostel Block at AIIMS, New Delhi:

Annexure-II

S.N.		Reference	Bidder's Query	Clarification
1	I	BOQ Page E-1 Item no. 1.01	As per BOQ Al bus bar shall be required	BOQ item is final
	II	Technical Spec page E-7, clause 3.1.3.1	As per specifications copper bus bar is required	
	III		Kindly clarify which type of bus bar to be considered	
2		H.T. Panel	We request you to kindly approve OEM authorized channel partner of VCB panel	No change in approved make list
3	I	BOQ page E-4, item 1.03	BOQ ask for out door transformer	BOQ item is final
	II	Technical Spec page E-95, clause 20	Sub-head "General" ask for indoor transformer & type is mentioned as out door transformer	
	III		Please clarify	
4		BOQ page E-4 item no 1.04	Please specify size of Al strip for earthing of bus duct	As required by relevant IS.
5		BOQ page E-4, item no 1.05	Please confirm whether HT cable is earthed type or unearthed type	As per clause no 3.2.1 at page E-10 of technical specifications the HT cable is earthed type.
6		BOQ page E-5, item no. 1.09	Please confirm the type of end termination for HT cable, indoor or out door	Termination in transformer : Out door Termination in panel: Indoor
7		BOQ page E-5, item no 1.11	Please confirm which type of manhole cover is required RCC or CI type.	We confirm that item no. 1.11 does not exist in this tender.
8		BOQ page E-14 item no. 3.01	Please confirm rising mains is sandwich type or air insulated type	Item no 3.01 is of DG set. We confirm Rising mains are not the part of this tender.
9		BOQ page E-30, item no. 7.01	Wiring for fan / exhaust fan/ light points has been asked along with	Quantity of ceiling fan and exhaust fans are as per item no. 8.03 & 8.04 of

			supply of fan boxes (in case of ceiling fan) & ceiling rose (in case of exhaust fan). Kindly provide quantity break-up for fan points & exhaust fan points respectively.	BOQ at page E-32
10		List of makes	Please provide approved makes for cable tray & Nurse call bell system	We confirm that Nurse call bell is not a part of this tender. Cable tray: The cable tray shall be of local fabrication. Make shall be decided during execution.
11		BOQ page E-42 item no. 10.01	Please confirm if supply of telephone cable is required in this item. If yes, please specify no. of pairs for telephone cable	BOQ item is very much clear. 2 pair telephone cable is part of the item.
12			Please confirm completion time for electrical works	As per Tender.
13		Point no. 4 of IVRCL letter no. IVRCL/DZO/2011-12/0882 dated 05.07.11	Detailed drawings	Change in the scope of detailed drawings is not acceptable.