



4TH FLOOR -
POST NATAL CARE WARD - 30 BEDS

S.ND.	DESCRIPTION	SIMBAL
1.	FIRE HOSE CABINET (FHC) (SIZE: 1200x600x210 MM HT)	
2.	SPRINKLER (PENDENT TYPE)	
3.	SPRINKLER PIPE	
4.	INSPECTION TEST VALVE ASSEMBLY (ITV)	
5.	NON RETURN VALVE	
6.	SLUICE VALVE	
7.	FIRE LINE	

FIRE EXTINGUISHER	
WATER TYPE FIRE EXTINGUISHER	
CARBON DIOXIDE TYPE FIRE EXTINGUISHER	
MANUAL CALL BOX	

NOTES ON FIRE FIGHTING

- Every FHC shall be consisting of as per IS the following:
 - 63mm dia. single headed hydrant Valve.
 - 63mm dia. 15m long H.C. hose reel.
 - 20m dia. 36.5m first use hose reel with 5m bore
 - 63mm dia. male and female INCT type coupling.
 - 20m dia. branch pipe with 20m nozzle.
- 2 NOS FIRE EXTINGUISHERS

REV	DATE	DESCRIPTION
REVISION		

PROJECT
NRHM PROJECT
Proposed 100
Bedded Hospital
at ALIGARH

TITLE PLUMBING

TENDER DRAWING
FOURTH FLOOR PLAN

Drawing No.

Job No. Scale Date

App by Rev. by Prep. by

HSCC (INDIA) LIMITED
(A GOVERNMENT OF INDIA ENTERPRISE)
HSCC
NEW DELHI INDIA