

Dated: 13.02.2017

All Bidders

Amendment-1

Subject: **Tender for** Package 1: Supply, installation, testing & commissioning of office furniture for Academic Block, Sr. resident Hostel, Jr. resident Hostel, Director's bungalow and Cafeteria and their maintenance during defect liability period & other associated works like minor civil, electrical, PHE works etc. at LGBRIMH, TEZPUR, ASSAM

Dear Sir,

This has reference to the pre bid meeting held on 08.02.2017 for captioned subject works,

Please find enclosed the revised specifications related to office furniture at Annexure-1 as an AMMENDMENT-1/CLARIFICATION-1 may be noted, which shall be treated as a part of subject tender.

Amendments to be submitted online duly signed & stamp along with tender. Other conditions of tender will remain unchanged.

Prospective bidders are advised to regularly scan through HSCC e-tender portal <http://www.tenderwizard.com/HSCC> and <http://www.hsccltd.co.in> as corrigendum/amendments etc., if any, will be notified on these websites only and separate advertisement will not be made for this.

Thanking you,

CGM (PG-I)
HSCC (I) Ltd

AMENDMENT-1

Name of the work : Package 1: Supply, installation, testing & commissioning of office furniture for Academic Block, Sr. resident Hostel, Jr. resident Hostel, Director's bungalow and Cafeteria and their maintenance during defect liability period & other associated works like minor civil, electrical, PHE works etc. at LGBRIMH, TEZPUR, ASSAM

Tender no : HSCC/LGBRIMH/ Hostel & office Fur/2017 Dated 25.01.2017

BOQ Item no	Queries	Clarifications/Amendment
	ACADEMIC BLOCK	
3.	Sofa 3 Seater	
	3 Seater sofa size given as 146cm x 92cmX 82cm . Which is for 2 Seater, Please Clarify Size required for 3 seater sofa.	Size for 3 Seater sofa may be read as 200-220 cmx92-100cmx82-100cm .
6	Desk for Library,Assistant Chief Librarian & Assistant Professor	
	In the specs ERU Size mentioned as -1550x450x725 In the specs HDU size mentioned as - 1280x425x705. Confirm if ERU OR HDU is required.	Provide – 1ERU and 1 HDU Storage, rest remain same.
7.	Mid Back chair for Assistant Professor	
	Please Confirm if the sizes of Seat & Back given in Specification are overall sizes.	Yes
8.	Visitor chair for Assistant Professor	
	For visitor chair ht of 580 is very big. Please confirm.	The height of Chair may be read as 450-475 mm.
10	Workstation	
	Workstation Size not mentioned. Partition height not clear. Overhead detail not clear.	Work surface Size shall be 1200 x 600. Partition height shall be 1200 mm. Overhead is not required.
15	Desk for Chief Librarian and professor.	
	In the Specification 2 drawer + 3 drawer mentioned – please confirm the size? Drawer Req with top hung or Pedestal?	Floor mounted pedestal Required on both side. Size of pedestal shall be 450-475mm Width x 570-600MM Depth x 725-750 MM Height
18	Storage unit	
	In specification dimension 900Wx450Dx1830H &	Size of storage unit shall be 900-

	1200WX450D both are mentioned. Please clarify the size of the unit required. (ii) In 1830 H sliding door arrangement is required. Please confirm if sliding door storage unit or Hinged door storage unit is required.	950(W)X400-450DX1800-1900(H). (ii) Hinged door unit may be considered.
19	As per specification/BOQ item no. 19 Conference Table 20 seater is mentioned and also the quantity required is 40 each. Please confirm	Conference table 2 nos. of 20 seats each i.e. total 40 seats required.
20	Main Desk for Associate professor.	
	i) Table top size is missing & specs are also not clear. ii) ERU –Required only as table or Storage	Table size shall be 1800 MM L x750MM W x750 MM H. Storage with open able shutter and open space for CPU required.
22	Desk for Classroom.	
	In the Specification Desk Depth is given as 750 mm, Please Clarify	Desk depth is required as 600-650 mm .
	<u>SENIOR RESIDENT</u>	
4.	Almirah	
	Removable Skirting is not possible.	The line" Removeable skirting to cover legs" is deleted.
8.	Curtain	
	i) Specs are not mentioned. ii) Sqm unit given – please Confirm how will it be measured?	i) Curtain complete with accessories and having fabric with backing of cotton marking with hanging rod & other accessories as approved by Engineer/Employer. ii) Curtain unit to be measured from the openable area of doors/windows .
11.	Double Bed	
	Specs & Size are not given	Please refer Specs Same as Director Bunglow item no -16
	<u>JUNIOR RESIDENT</u>	
1	Desk for Warden's office.	
	In the specs ERU Size mentioned as -1550x450x725 In the specs HDU size mentioned as -1280x425x705 Pls confirm if ERU OR HDU is required ?	Required and Same as, academic block item no -6
2	Chair for Warden	

	Please Confirm if the size of Seat & Back given in Specification are overall sizes.	Same as, academic block item no -16
3.	Visitor chair for warden	
	For visitor chair ht of 580 is very big. Please confirm.	Same as, academic block item no -8
17.	Playing Desk	
	Size not given	Shall shall be 1200 mm x900 mm
	<u>DIRECTOR'S BUNGLOW</u>	
5.	T.V rack	
	Size not clear. Specs also not Clear	TV unit size shall be 1600-1650 mm x 450-480 mm x 1550-1600mm with T.V Space as 850-900 mm x450-480 mm x 800- 850mm. T.V unit is made up of 18mm prelamated particle board/MDF comprising of Ample open storage space below the T.V & 2 openable shutter on both side of the unit at bottom and 2 tower glass unit above as approved by Engineer/Employer
6	Book case	
	In the Specs size of book case is given as 314mm (w) which is not practically feasible. Please confirm.	Book case size shall be 900-914mm (w) x 320-370 mm (D) x 1700- 1742 mm(H)
8	Desk for office/ Library	
	Table & Back unit Size not Clear. Please Clarify	Please Provide Table with drawer of size- 1500-1600 mm Wx700-750 mm D x750-800 mm H and side unit of size 900-950 mm x450-500 mm x700-800 mm H having open able shutters and HDU of size 900-950 mm x450-500 mm x00-800 mm with openable shutter.
16.	Bed room Set	
	Bed side table mentioned – Please clarify the qty of bed side table required.	2 nos of bed side table shall be Provided.
17.	Refrigerator	
	Please confirm the Capacity required .	Capacity shall be 300 Litre.
21.	Curtain	
	i) Specs are not mentioned ii) Sqm unit given – please Confirm how will it be measured	Same as, Senior Resident.
	<u>CAFETARIA</u>	

1	Cafeteria Desk	
	Size not given	Size shall be 1000-1050 mm x1050-1100 mm x750-800mm.
3.	Sofa 3 Seater	
	Size mentioned in specs is 545mm(w) x467mm(d)x125mm (t) , which is not correct. Please clarify	Size of 3 Seater sofa shall be 2000-2100 mm(w)x800-900mm(d)x820-850mm(h).
4	Sofa 2 Seater	
	Size mentioned in specs is 545mm(w) x467mm(d)x125mm (t) , which is not correct. Please clarify	Size of 2 Seater sofa as 1460-1600mm (w)x800-900mm(d)x820-850mm(h).
7	Curtain	
	i) Specs are not mentioned ii) Sqm unit given – please Confirm how will it be measured?	Same as, Senior Resident.
9.	Refrigerator	
	Please confirm the Capacity-Required	Capacity shall be 400 Litre.
	Please permit +/- 10% variation in chair sizes	No change
	For furniture sustainability standard and also for better environment BIFMAe 3 certificate may also be required to be submitted along with bid	