

<b>Clarifications regarding HVAC System for Construction of Hostel Block 1,2&amp;3 at AIIMS, New Delhi..</b>		
<b>S. No.</b>	<b>Bidders Query</b>	<b>Annexure-III Clarifications</b>
1	Hot water Pump Type	Not Applicable
2	Air Handling Unit- we have not included any kind of foundation and supporting arrangement for the same.	Not Applicable
3	Split Air Conditioner - For item no. 7.0, we will quote our standard Blue Star make ductable unit with standard filter.	Not Applicable
4	a) Tube Axial fan RPM 1440 in case of fire b) Diameter, RPM, Outlet velocity for axial, centrifugal fans as per selection software of manufactures.	Shall be as per tender document. Shall be as per tender document.
	c) Noise Level from the AHU, Axial And cetrifugal fan motor/fan shall be according to manufacturer's standards and the same will be taken care by providing accoustic insulation	Shall be as per tender document.
5	Ducting We will offer factory fabricated ducting as per standard. Ducting shall be fabricated from class VIII(120 GSM) galvanised steel sheet.Kindly quantify the fire rated ducting separately to enable us to quote the same.275 GSM duct is not easily available. Please Specify the approved make for factory fabricated ducting if the ducting is to be considered as factory fabricated ducting.	Shall be as per tender document.Gauge for fire rated ducting shall be as per BOQ. Quantities shall be as per tender documents. Shall be as per tender document.
6	Smoke sensor will not be part of HVAC .	Shall be as per tender document.
7	Square/Circular Diffuser	Shall be as per tender document.
8	ACB and MCB shall be non draw out type	Shall be as per tender document.
9	Control Console Control wiring will be done in item no.39, we will not include the wiring with item no.40.0	Not Applicable
10	Additional make approvals.	Shall be as per tender document.